

## Drinking water Sampling and Analysis for Lead (Pb)

### Codes for sampling points.

**WC** = water cooler (chiller unit)  
**CF** = classroom faucet  
**KC** = kitchen faucet, cold  
**EC** = home economics room, cold  
**IM** = Ice Machine  
**NS** = nurse's office sink  
**SC** = service connector  
**LAV** = Lavatory sink (cold)  
**SS** = Slop Sink (i.e. Custodial closet)  
**FSC** = Faculty Sink Cold

### How to sample?

Basic sampling protocol: This is an overview of the sampling procedures.  
 Determine which outlets will be sampled. Determine priorities and code outlets appropriately.  
**Outlets must be inactive for at least 8 hours before testing. (Overnight is best.)**  
 Take a "first draw" 250 ml\*\* sample at each outlet.

**School District Name:** Jamesville DeWitt CSD

**Building Name:** Jamesville Elementary

Sample No.	Description	Date/Time Sampled	Location of Water Outlet (i.e. Rm #, near xx)	Type of Outlet (i.e. Sink, DF)	(if DF - model No.)	Notes
1	First Flush	09/23/16 04:56	Kitchen hand sink	kc		by entry door
2	" "	09/23/16 04:56	kitchen prep area	kc		left
3	" "	09/23/16 04:56	kitchen prep area	kc		right
4	" "	09/23/16 04:58	Kitchen pot wash	kc		left
5	" "	09/23/16 05:58	Kitchen pot wash	kc		right
6	" "	09/23/16 04:58	Kitchen pot wash	kc		hand sink
100	" "	09/23/16 05:00	Cafeteria	WC	Elkay	
7	" "	09/23/16 05:00	Cafeteria	WC	Elkay	
8	" "	09/23/16 05:00	Faculty	LAV		Downstairs
9	" "	09/23/16 05:00	girls	LAV		Downstairs
10	" "	09/23/16 05:00	boys	LAV		Downstairs
11	" "	09/23/16 05:05	Faculty lounge	WC		Downstairs
12	" "	09/23/16 05:15	Faculty hall	LAV		Downstairs
13	" "	09/23/16 05:16	Band room	CF		
14	" "	09/23/16 05:17	PT room	CF		
15	" "	09/23/16 05:18	PT room	WC		
16	" "	09/23/16 05:20	301	CF		
17	" "	09/23/16 05:20	301	WC		
18	" "	09/23/16 05:22	303	CF		
19	" "	09/23/16 05:22	303	WC		
20	" "	09/23/16 05:25	305	CF		
21	" "	09/23/16 05:25	305	WC		
22	" "	09/23/16 05:27	304	CF		
23	" "	09/23/16 05:27	304	WC		
24	" "	09/23/16 05:30	4th grade	WC		Left
25	" "	09/23/16 05:30	4th grade	WC		right
26	" "	09/23/16 05:30	212	WC		
27	" "	09/23/16 05:30	212	CF		
28	" "	09/23/16 05:32	Art Room North	CF		left
29	" "	09/23/16 05:32	Art Room North	CF		right
30	" "	09/23/16 05:32	Art Room North	CF		center
31	" "	09/23/16 05:35	Art Room South	cf		right
32	" "	09/23/16 05:35	Art Room South	CF		center
33	" "	09/23/16 05:35	Art Room South	CF		left
34	" "	09/23/16 05:35	pottery room	CF		
35	" "	09/23/16 05:37	210	CF		
36	" "	09/23/16 05:37	208	CF		
37	" "	09/23/16 05:38	209	CF		
38	" "	09/23/16 05:39	209	WC		

39	" "	09/23/16 05:41	207	CF		
40	" "	09/23/16 05:40	206	WC		

Drinking water Sampling and Analysis for Lead (Pb)

Sample No.	Description	Date/Time Sampled	Location of Water Outlet (i.e. Rm #, near xx)	Type of Outlet (i.e. In, DF)	(if DF - model No.)	Notes
41	First Flush	09/23/16 05:40	206	CF		
42	" "	09/23/16 05:41	207	WC		
43	" "	09/23/16 05:43	204	WC		
44	" "	09/23/16 05:43	204	CF		
45	" "	09/23/16 05:45	202	CF		
46	" "	09/23/16 05:45	205	CF		North
47	" "	09/23/16 05:46	205	WC		North
48	" "	09/23/16 05:46	205	CF		South
49	" "	09/23/16 05:49	Library	CF		North
50	" "	09/23/16 05:49	Library	CF		Center
51	" "	09/23/16 05:54	201	CF		
52	" "	09/23/16 05:53	203	CF		South
53	" "	09/23/16 05:53	203	CF		North
54	" "	09/23/16 05:53	203	WC		North
55	" "	09/23/16 05:55	Staff Room	LAV		
56	" "	09/23/16 05:56	111	CF		Porcelain sink
57	" "	09/23/16 05:56	111	CF		Steel Sink
58	" "	09/23/16 05:58	109	CF		Steel Sink
59	" "	09/23/16 05:58	109	CF		Porcelain sink
60	" "	09/23/16 06:00	106	WC		
61	" "	09/23/16 06:00	106	CF		West
62	" "	09/23/16 06:00	106	CF		East
63	" "	09/23/16 06:02	107	CF		Aid Room
64	" "	09/23/16 06:02	107	WC		
65	" "	09/23/16 06:02	107	LAV		
66	" "	09/23/16 06:05	105	CF		West
67	" "	09/23/16 06:04	104	CF		East
68	" "	09/23/16 06:05	104	CF		West
69	" "	09/23/16 06:04	104	WC		
70	" "	09/23/16 06:05	105	CF		East
71	" "	09/23/16 06:05	105	WC		
72	" "	09/23/16 06:08	102	CF		West
73	" "					
74	" "					
75	" "					
76	" "					
77	" "					
78	" "					
79	" "					
80	" "					