



# Life Science Laboratories, Inc.

Date Printed: 12/8/20

## Laboratory Analysis Report Prepared For Jamesville Dewitt Central School Dist.

Client Project ID: Tecumseh Elementary School / Lead Study

LSL Project ID: 2017894

**Tish Hauser**  
Jamesville Dewitt Central School Dist.  
P.O. Box 606  
Dewitt, NY 13214

Phone: (315) 445-8300  
FAX: (315) 445-8477  
Authorization: 21-00699

*A copy of this report was sent to: Jason Crawford  
Jamesville Dewitt Central School Dist.*

<b>Sample ID:</b> Lead Study	<b>LSL Sample ID:</b> 2017894-001
<b>Location:</b>	<b>Receive Date/Time:</b> 10/28/20 13:20
<b>Sampled:</b> 10/28/20 5:10	<b>Project Rec'd by:</b> gis1
<b>Sampled By:</b>	<b>Matrix:</b> PW

Analytical Method	Prep Method	Prep Date	Analysis Date & Time	Analyst Initials
Analyte	Result Units			

(1) Lead Study				
Number of Samples	66			MT

*Please refer to the chain of custody form on the last page of this report for the detailed descriptions of where these samples were taken.*

Life Science Laboratories, Inc. warrants, to the best of its knowledge and belief, the accuracy of the analytical test results contained in this report, but makes no other warranty, expressed or implied, especially no warranties of merchantability or fitness for a particular purpose. By the Client's acceptance and/or use of this report, the Client agrees that LSL is hereby released from any and all liabilities, claims, damages or causes of action affecting or which may affect the Client as regards to the results contained in this report. The Client further agrees that the only remedy available to the Client in the event of proven non-conformity with the above warranty shall be for LSL to re-perform the analytical test(s) at no charge to the Client. The data contained in this report are for the exclusive use of the Client to whom it is addressed, and the release of these data to any other party, or the use of the name, trademark or service mark of Life Science Laboratories, Inc. especially for the use of advertising to the general public, is strictly prohibited without express prior written consent of Life Science Laboratories, Inc. This report may only be reproduced in its entirety. No partial duplication is allowed. The Chain of Custody and the Sample Receipt documents submitted with these samples are considered by LSL to be an appendix of this report and may contain data qualifiers and specific information that pertains to the samples included in this report. The analytical result(s) in this report are only representative of the sample(s) submitted for analysis. LSL makes no claim of a sample's representativeness, or integrity, if sampling was not performed by LSL personnel.

LSL Central Lab  
5854 Butternut Drive  
East Syracuse, NY 13057  
Tel. (315) 445-1900  
Fax (315) 445-1104  
NYS DOH ELAP #10248

LSL North Lab  
131 St. Lawrence Avenue  
Waddington, NY 13694  
Tel. (315) 388-4476  
Fax (315) 388-4061  
NYS DOH ELAP #10900

LSL Finger Lakes Lab  
16 N. Main St., PO Box 424  
Wayland, NY 14572  
Tel. (585) 213-4090  
Fax (585) 213-4192  
NYS DOH ELAP #11667

LSL Southern Tier Office  
Cuba, NY  
Tel. (585) 209-4032

LSL MidLakes Office  
Canandaigua, NY  
Tel. (585) 728-3320

Reviewed by: *Kristin E. Carpenter*  
**Kristin E. Carpenter, Quality Staff**

Date: 12/08/20

Analysis performed at: (1) LSL Central Lab, (2) LSL North Lab, (3) LSL Finger Lakes Lab



**Life Science Laboratories, Inc.**  
 5854 Butternut Drive  
 East Syracuse , NY 13057 (315) 445-1900

# Analytical Results

State Certification No: 10248

**CLIENT:** Life Science Labs-LIMS  
**Project:** Jamesville Dewitt Central School Dist.  
**Location:** Tecumseh Elementary School / Lead Study  
**Matrix:** PWS

**Client Sample ID:** TE-001

**Lab ID:** 2017894-001A  
**Collection Date:** 10/28/20 5:10  
**Date Received:** 10/28/20 13:20

Analyte	Result and Qualifiers	Units	Date Analyzed
<b>METALS BY ICPMS</b>		<b>EPA 200.8,Rev.5.4</b>	<b>(EPA 200.2)</b>
Lead	< 0.0010	mg/L	11/20/20 19:50

**Qualifiers:**

- \* Value may exceed the Acceptable Level
- E Value exceeds the instrument calibration range
- J Analyte detected below the PQL
- P Prim./Conf. column %D or RPD exceeds limit

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Practical Quantitation Limit (PQL)
- S Spike Recovery outside accepted recovery limits



**Life Science Laboratories, Inc.**  
 5854 Butternut Drive  
 East Syracuse, NY 13057 (315) 445-1900

# Analytical Results

State Certification No: 10248

**CLIENT:** Life Science Labs-LIMS  
**Project:** Jamesville Dewitt Central School Dist.  
**Location:** Tecumseh Elementary School / Lead Study  
**Matrix:** PWS

**Client Sample ID:** TE-002  
**Lab ID:** 2017894-002A  
**Collection Date:** 10/28/20 5:13  
**Date Received:** 10/28/20 13:20

Analyte	Result and Qualifiers	Units	Date Analyzed
<b>METALS BY ICPMS</b>		<b>EPA 200.8,Rev.5.4</b>	<b>(EPA 200.2)</b>
Lead	< 0.0010	mg/L	11/20/20 19:56

**Qualifiers:**

- \* Value may exceed the Acceptable Level
- E Value exceeds the instrument calibration range
- J Analyte detected below the PQL
- P Prim./Conf. column %D or RPD exceeds limit

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Practical Quantitation Limit (PQL)
- S Spike Recovery outside accepted recovery limits



**Life Science Laboratories, Inc.**  
 5854 Butternut Drive  
 East Syracuse, NY 13057 (315) 445-1900

# Analytical Results

State Certification No: 10248

**CLIENT:** Life Science Labs-LIMS  
**Project:** Jamesville Dewitt Central School Dist.  
**Location:** Tecumseh Elementary School / Lead Study  
**Matrix:** PWS

**Client Sample ID:** TE-003

**Lab ID:** 2017894-003A  
**Collection Date:** 10/28/20 5:25  
**Date Received:** 10/28/20 13:20

Analyte	Result and Qualifiers	Units	Date Analyzed
<b>METALS BY ICPMS</b>		<b>EPA 200.8,Rev.5.4</b>	<b>(EPA 200.2)</b>
Lead	< 0.0010	mg/L	11/20/20 19:58

**Qualifiers:**

- \* Value may exceed the Acceptable Level
- E Value exceeds the instrument calibration range
- J Analyte detected below the PQL
- P Prim./Conf. column %D or RPD exceeds limit

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Practical Quantitation Limit (PQL)
- S Spike Recovery outside accepted recovery limits



**Life Science Laboratories, Inc.**  
 5854 Butternut Drive  
 East Syracuse, NY 13057 (315) 445-1900

# Analytical Results

State Certification No: 10248

**CLIENT:** Life Science Labs-LIMS  
**Project:** Jamesville Dewitt Central School Dist.  
**Location:** Tecumseh Elementary School / Lead Study  
**Matrix:** PWS

**Client Sample ID:** TE-004  
**Lab ID:** 2017894-004A  
**Collection Date:** 10/28/20 5:28  
**Date Received:** 10/28/20 13:20

Analyte	Result and Qualifiers	Units	Date Analyzed
<b>METALS BY ICPMS</b>		<b>EPA 200.8,Rev.5.4</b>	<b>(EPA 200.2)</b>
Lead	0.0059	mg/L	11/20/20 20:00

- Qualifiers:**
- \* Value may exceed the Acceptable Level
  - E Value exceeds the instrument calibration range
  - J Analyte detected below the PQL
  - P Prim./Conf. column %D or RPD exceeds limit
  - B Analyte detected in the associated Method Blank
  - H Holding times for preparation or analysis exceeded
  - ND Not Detected at the Practical Quantitation Limit (PQL)
  - S Spike Recovery outside accepted recovery limits



**Life Science Laboratories, Inc.**  
 5854 Butternut Drive  
 East Syracuse, NY 13057 (315) 445-1900

# Analytical Results

State Certification No: 10248

**CLIENT:** Life Science Labs-LIMS  
**Project:** Jamesville Dewitt Central School Dist.  
**Location:** Tecumseh Elementary School / Lead Study  
**Matrix:** PWS

**Client Sample ID:** TE-005

**Lab ID:** 2017894-005A  
**Collection Date:** 10/28/20 5:30  
**Date Received:** 10/28/20 13:20

Analyte	Result and Qualifiers	Units	Date Analyzed
<b>METALS BY ICPMS</b>		<b>EPA 200.8,Rev.5.4</b>	<b>(EPA 200.2)</b>
Lead	0.0012	mg/L	11/20/20 20:02

- Qualifiers:**
- \* Value may exceed the Acceptable Level
  - E Value exceeds the instrument calibration range
  - J Analyte detected below the PQL
  - P Prim./Conf. column %D or RPD exceeds limit
  - B Analyte detected in the associated Method Blank
  - H Holding times for preparation or analysis exceeded
  - ND Not Detected at the Practical Quantitation Limit (PQL)
  - S Spike Recovery outside accepted recovery limits



**Life Science Laboratories, Inc.**  
 5854 Butternut Drive  
 East Syracuse, NY 13057 (315) 445-1900

# Analytical Results

State Certification No: 10248

**CLIENT:** Life Science Labs-LIMS  
**Project:** Jamesville Dewitt Central School Dist.  
**Location:** Tecumseh Elementary School / Lead Study  
**Matrix:** PWS

**Client Sample ID:** TE-006  
**Lab ID:** 2017894-006A  
**Collection Date:** 10/28/20 5:32  
**Date Received:** 10/28/20 13:20

Analyte	Result and Qualifiers	Units	Date Analyzed
<b>METALS BY ICPMS</b>		<b>EPA 200.8,Rev.5.4</b>	<b>(EPA 200.2)</b>
Lead	0.0012	mg/L	11/20/20 20:04

- Qualifiers:**
- \* Value may exceed the Acceptable Level
  - E Value exceeds the instrument calibration range
  - J Analyte detected below the PQL
  - P Prim./Conf. column %D or RPD exceeds limit
  - B Analyte detected in the associated Method Blank
  - H Holding times for preparation or analysis exceeded
  - ND Not Detected at the Practical Quantitation Limit (PQL)
  - S Spike Recovery outside accepted recovery limits



**Life Science Laboratories, Inc.**  
 5854 Butternut Drive  
 East Syracuse , NY 13057 (315) 445-1900

# Analytical Results

State Certification No: 10248

**CLIENT:** Life Science Labs-LIMS  
**Project:** Jamesville Dewitt Central School Dist.  
**Location:** Tecumseh Elementary School / Lead Study  
**Matrix:** PWS

**Client Sample ID:** TE-007

**Lab ID:** 2017894-007A  
**Collection Date:** 10/28/20 5:33  
**Date Received:** 10/28/20 13:20

Analyte	Result and Qualifiers	Units	Date Analyzed
<b>METALS BY ICPMS</b>		<b>EPA 200.8,Rev.5.4</b>	<b>(EPA 200.2)</b>
Lead	< 0.0010	mg/L	11/20/20 20:06

- Qualifiers:**
- \* Value may exceed the Acceptable Level
  - E Value exceeds the instrument calibration range
  - J Analyte detected below the PQL
  - P Prim./Conf. column %D or RPD exceeds limit
  - B Analyte detected in the associated Method Blank
  - H Holding times for preparation or analysis exceeded
  - ND Not Detected at the Practical Quantitation Limit (PQL)
  - S Spike Recovery outside accepted recovery limits





**Life Science Laboratories, Inc.**  
 5854 Butternut Drive  
 East Syracuse, NY 13057 (315) 445-1900

# Analytical Results

State Certification No: 10248

**CLIENT:** Life Science Labs-LIMS  
**Project:** Jamesville Dewitt Central School Dist.  
**Location:** Tecumseh Elementary School / Lead Study  
**Matrix:** PWS

**Client Sample ID:** TE-008

**Lab ID:** 2017894-008A  
**Collection Date:** 10/28/20 5:35  
**Date Received:** 10/28/20 13:20

Analyte	Result and Qualifiers	Units	Date Analyzed
<b>METALS BY ICPMS</b>		<b>EPA 200.8,Rev.5.4</b>	<b>(EPA 200.2)</b>
Lead	0.0058	mg/L	11/20/20 20:08

- Qualifiers:**
- \* Value may exceed the Acceptable Level
  - E Value exceeds the instrument calibration range
  - J Analyte detected below the PQL
  - P Prim./Conf. column %D or RPD exceeds limit
  - B Analyte detected in the associated Method Blank
  - H Holding times for preparation or analysis exceeded
  - ND Not Detected at the Practical Quantitation Limit (PQL)
  - S Spike Recovery outside accepted recovery limits



**Life Science Laboratories, Inc.**  
 5854 Butternut Drive  
 East Syracuse , NY 13057 (315) 445-1900

# Analytical Results

State Certification No: 10248

**CLIENT:** Life Science Labs-LIMS  
**Project:** Jamesville Dewitt Central School Dist.  
**Location:** Tecumseh Elementary School / Lead Study  
**Matrix:** PWS

**Client Sample ID:** TE-009  
**Lab ID:** 2017894-009A  
**Collection Date:** 10/28/20 5:38  
**Date Received:** 10/28/20 13:20

Analyte	Result and Qualifiers	Units	Date Analyzed
<b>METALS BY ICPMS</b>		<b>EPA 200.8,Rev.5.4</b>	<b>(EPA 200.2)</b>
Lead	0.0064	mg/L	11/20/20 20:14

- Qualifiers:**
- \* Value may exceed the Acceptable Level
  - E Value exceeds the instrument calibration range
  - J Analyte detected below the PQL
  - P Prim./Conf. column %D or RPD exceeds limit
  - B Analyte detected in the associated Method Blank
  - H Holding times for preparation or analysis exceeded
  - ND Not Detected at the Practical Quantitation Limit (PQL)
  - S Spike Recovery outside accepted recovery limits



**Life Science Laboratories, Inc.**  
 5854 Butternut Drive  
 East Syracuse, NY 13057 (315) 445-1900

# Analytical Results

State Certification No: 10248

**CLIENT:** Life Science Labs-LIMS  
**Project:** Jamesville Dewitt Central School Dist.  
**Location:** Tecumseh Elementary School / Lead Study  
**Matrix:** PWS

**Client Sample ID:** TE-010

**Lab ID:** 2017894-010A  
**Collection Date:** 10/28/20 5:40  
**Date Received:** 10/28/20 13:20

Analyte	Result and Qualifiers	Units	Date Analyzed
<b>METALS BY ICPMS</b>		<b>EPA 200.8,Rev.5.4</b>	<b>(EPA 200.2)</b>
Lead	0.0025	mg/L	11/20/20 20:16

- Qualifiers:**
- \* Value may exceed the Acceptable Level
  - E Value exceeds the instrument calibration range
  - J Analyte detected below the PQL
  - P Prim./Conf. column %D or RPD exceeds limit
  - B Analyte detected in the associated Method Blank
  - H Holding times for preparation or analysis exceeded
  - ND Not Detected at the Practical Quantitation Limit (PQL)
  - S Spike Recovery outside accepted recovery limits



**Life Science Laboratories, Inc.**  
 5854 Butternut Drive  
 East Syracuse, NY 13057 (315) 445-1900

# Analytical Results

State Certification No: 10248

**CLIENT:** Life Science Labs-LIMS  
**Project:** Jamesville Dewitt Central School Dist.  
**Location:** Tecumseh Elementary School / Lead Study  
**Matrix:** PWS

**Client Sample ID:** TE-011

**Lab ID:** 2017894-011A  
**Collection Date:** 10/28/20 5:42  
**Date Received:** 10/28/20 13:20

Analyte	Result and Qualifiers	Units	Date Analyzed
<b>METALS BY ICPMS</b>		<b>EPA 200.8,Rev.5.4</b>	<b>(EPA 200.2)</b>
Lead	0.010	mg/L	11/20/20 20:18

- Qualifiers:**
- \* Value may exceed the Acceptable Level
  - E Value exceeds the instrument calibration range
  - J Analyte detected below the PQL
  - P Prim./Conf. column %D or RPD exceeds limit
  - B Analyte detected in the associated Method Blank
  - H Holding times for preparation or analysis exceeded
  - ND Not Detected at the Practical Quantitation Limit (PQL)
  - S Spike Recovery outside accepted recovery limits



**Life Science Laboratories, Inc.**  
 5854 Butternut Drive  
 East Syracuse , NY 13057 (315) 445-1900

# Analytical Results

State Certification No: 10248

**CLIENT:** Life Science Labs-LIMS  
**Project:** Jamesville Dewitt Central School Dist.  
**Location:** Tecumseh Elementary School / Lead Study  
**Matrix:** PWS

**Client Sample ID:** TE-012  
**Lab ID:** 2017894-012A  
**Collection Date:** 10/28/20 5:44  
**Date Received:** 10/28/20 13:20

Analyte	Result and Qualifiers	Units	Date Analyzed
<b>METALS BY ICPMS</b>		<b>EPA 200.8,Rev.5.4</b>	<b>(EPA 200.2)</b>
Lead	0.017 *	mg/L	11/20/20 20:20

- Qualifiers:**
- \* Value may exceed the Acceptable Level
  - E Value exceeds the instrument calibration range
  - J Analyte detected below the PQL
  - P Prim./Conf. column %D or RPD exceeds limit
  - B Analyte detected in the associated Method Blank
  - H Holding times for preparation or analysis exceeded
  - ND Not Detected at the Practical Quantitation Limit (PQL)
  - S Spike Recovery outside accepted recovery limits



**Life Science Laboratories, Inc.**  
 5854 Butternut Drive  
 East Syracuse , NY 13057 (315) 445-1900

# Analytical Results

State Certification No: 10248

**CLIENT:** Life Science Labs-LIMS  
**Project:** Jamesville Dewitt Central School Dist.  
**Location:** Tecumseh Elementary School / Lead Study  
**Matrix:** PWS

**Client Sample ID:** TE-013  
**Lab ID:** 2017894-013A  
**Collection Date:** 10/28/20 5:46  
**Date Received:** 10/28/20 13:20

Analyte	Result and Qualifiers	Units	Date Analyzed
<b>METALS BY ICPMS</b>		<b>EPA 200.8,Rev.5.4</b>	<b>(EPA 200.2)</b>
Lead	0.0017	mg/L	11/20/20 20:22

- Qualifiers:**
- \* Value may exceed the Acceptable Level
  - E Value exceeds the instrument calibration range
  - J Analyte detected below the PQL
  - P Prim./Conf. column %D or RPD exceeds limit
  - B Analyte detected in the associated Method Blank
  - H Holding times for preparation or analysis exceeded
  - ND Not Detected at the Practical Quantitation Limit (PQL)
  - S Spike Recovery outside accepted recovery limits



**Life Science Laboratories, Inc.**  
 5854 Butternut Drive  
 East Syracuse , NY 13057 (315) 445-1900

# Analytical Results

State Certification No: 10248

**CLIENT:** Life Science Labs-LIMS  
**Project:** Jamesville Dewitt Central School Dist.  
**Location:** Tecumseh Elementary School / Lead Study  
**Matrix:** PWS

**Client Sample ID:** *TE-014*  
**Lab ID:** 2017894-014A  
**Collection Date:** 10/28/20 5:48  
**Date Received:** 10/28/20 13:20

Analyte	Result and Qualifiers	Units	Date Analyzed
<b>METALS BY ICPMS</b>		<b>EPA 200.8,Rev.5.4</b>	<b>(EPA 200.2)</b>
Lead	0.0098	mg/L	11/20/20 20:24

- Qualifiers:**
- \* Value may exceed the Acceptable Level
  - E Value exceeds the instrument calibration range
  - J Analyte detected below the PQL
  - P Prim./Conf. column %D or RPD exceeds limit
  - B Analyte detected in the associated Method Blank
  - H Holding times for preparation or analysis exceeded
  - ND Not Detected at the Practical Quantitation Limit (PQL)
  - S Spike Recovery outside accepted recovery limits



**Life Science Laboratories, Inc.**  
 5854 Butternut Drive  
 East Syracuse, NY 13057 (315) 445-1900

# Analytical Results

State Certification No: 10248

**CLIENT:** Life Science Labs-LIMS  
**Project:** Jamesville Dewitt Central School Dist.  
**Location:** Tecumseh Elementary School / Lead Study  
**Matrix:** PWS

**Client Sample ID:** TE-015  
**Lab ID:** 2017894-015A  
**Collection Date:** 10/28/20 5:45  
**Date Received:** 10/28/20 13:20

Analyte	Result and Qualifiers	Units	Date Analyzed
<b>METALS BY ICPMS</b>		<b>EPA 200.8,Rev.5.4</b>	<b>(EPA 200.2)</b>
Lead	0.0054	mg/L	11/20/20 20:26

- Qualifiers:**
- \* Value may exceed the Acceptable Level
  - E Value exceeds the instrument calibration range
  - J Analyte detected below the PQL
  - P Prim./Conf. column %D or RPD exceeds limit
  - B Analyte detected in the associated Method Blank
  - H Holding times for preparation or analysis exceeded
  - ND Not Detected at the Practical Quantitation Limit (PQL)
  - S Spike Recovery outside accepted recovery limits





**Life Science Laboratories, Inc.**  
 5854 Butternut Drive  
 East Syracuse , NY 13057 (315) 445-1900

# Analytical Results

State Certification No: 10248

**CLIENT:** Life Science Labs-LIMS  
**Project:** Jamesville Dewitt Central School Dist.  
**Location:** Tecumseh Elementary School / Lead Study  
**Matrix:** PWS

**Client Sample ID:** TE-016

**Lab ID:** 2017894-016A  
**Collection Date:** 10/28/20 5:48  
**Date Received:** 10/28/20 13:20

Analyte	Result and Qualifiers	Units	Date Analyzed
<b>METALS BY ICPMS</b>		<b>EPA 200.8,Rev.5.4</b>	<b>(EPA 200.2)</b>
Lead	0.0033	mg/L	11/25/20 12:14

- Qualifiers:**
- \* Value may exceed the Acceptable Level
  - E Value exceeds the instrument calibration range
  - J Analyte detected below the PQL
  - P Prim./Conf. column %D or RPD exceeds limit
  - B Analyte detected in the associated Method Blank
  - H Holding times for preparation or analysis exceeded
  - ND Not Detected at the Practical Quantitation Limit (PQL)
  - S Spike Recovery outside accepted recovery limits



**Life Science Laboratories, Inc.**  
 5854 Butternut Drive  
 East Syracuse , NY 13057 (315) 445-1900

# Analytical Results

State Certification No: 10248

**CLIENT:** Life Science Labs-LIMS  
**Project:** Jamesville Dewitt Central School Dist.  
**Location:** Tecumseh Elementary School / Lead Study  
**Matrix:** PWS

**Client Sample ID:** TE-017  
**Lab ID:** 2017894-017A  
**Collection Date:** 10/28/20 5:50  
**Date Received:** 10/28/20 13:20

Analyte	Result and Qualifiers	Units	Date Analyzed
<b>METALS BY ICPMS</b>		<b>EPA 200.8,Rev.5.4</b>	<b>(EPA 200.2)</b>
Lead	0.0019	mg/L	11/20/20 20:28

- Qualifiers:**
- \* Value may exceed the Acceptable Level
  - E Value exceeds the instrument calibration range
  - J Analyte detected below the PQL
  - P Prim./Conf. column %D or RPD exceeds limit
  - B Analyte detected in the associated Method Blank
  - H Holding times for preparation or analysis exceeded
  - ND Not Detected at the Practical Quantitation Limit (PQL)
  - S Spike Recovery outside accepted recovery limits



**Life Science Laboratories, Inc.**  
 5854 Butternut Drive  
 East Syracuse , NY 13057 (315) 445-1900

# Analytical Results

State Certification No: 10248

**CLIENT:** Life Science Labs-LIMS  
**Project:** Jamesville Dewitt Central School Dist.  
**Location:** Tecumseh Elementary School / Lead Study  
**Matrix:** PWS

**Client Sample ID:** TE-018  
**Lab ID:** 2017894-018A  
**Collection Date:** 10/28/20 5:51  
**Date Received:** 10/28/20 13:20

Analyte	Result and Qualifiers	Units	Date Analyzed
<b>METALS BY ICPMS</b>		<b>EPA 200.8,Rev.5.4</b>	<b>(EPA 200.2)</b>
Lead	0.0022	mg/L	11/20/20 20:30

- Qualifiers:**
- \* Value may exceed the Acceptable Level
  - E Value exceeds the instrument calibration range
  - J Analyte detected below the PQL
  - P Prim./Conf. column %D or RPD exceeds limit
  - B Analyte detected in the associated Method Blank
  - H Holding times for preparation or analysis exceeded
  - ND Not Detected at the Practical Quantitation Limit (PQL)
  - S Spike Recovery outside accepted recovery limits



**Life Science Laboratories, Inc.**  
 5854 Butternut Drive  
 East Syracuse, NY 13057 (315) 445-1900

# Analytical Results

State Certification No: 10248

**CLIENT:** Life Science Labs-LIMS  
**Project:** Jamesville Dewitt Central School Dist.  
**Location:** Tecumseh Elementary School / Lead Study  
**Matrix:** PWS

**Client Sample ID:** TE-019  
**Lab ID:** 2017894-019A  
**Collection Date:** 10/28/20 5:52  
**Date Received:** 10/28/20 13:20

Analyte	Result and Qualifiers	Units	Date Analyzed
<b>METALS BY ICPMS</b>		<b>EPA 200.8,Rev.5.4</b>	<b>(EPA 200.2)</b>
Lead	0.0040	mg/L	11/20/20 20:32

- Qualifiers:**
- \* Value may exceed the Acceptable Level
  - E Value exceeds the instrument calibration range
  - J Analyte detected below the PQL
  - P Prim./Conf. column %D or RPD exceeds limit
  - B Analyte detected in the associated Method Blank
  - H Holding times for preparation or analysis exceeded
  - ND Not Detected at the Practical Quantitation Limit (PQL)
  - S Spike Recovery outside accepted recovery limits



**Life Science Laboratories, Inc.**  
 5854 Butternut Drive  
 East Syracuse, NY 13057 (315) 445-1900

# Analytical Results

State Certification No: 10248

**CLIENT:** Life Science Labs-LIMS  
**Project:** Jamesville Dewitt Central School Dist.  
**Location:** Tecumseh Elementary School / Lead Study  
**Matrix:** PWS

**Client Sample ID:** *TE-020*  
**Lab ID:** 2017894-020A  
**Collection Date:** 10/28/20 5:53  
**Date Received:** 10/28/20 13:20

Analyte	Result and Qualifiers	Units	Date Analyzed
<b>METALS BY ICPMS</b>		<b>EPA 200.8,Rev.5.4</b>	<b>(EPA 200.2)</b>
Lead	0.020 *	mg/L	11/20/20 20:38

- Qualifiers:**
- \* Value may exceed the Acceptable Level
  - E Value exceeds the instrument calibration range
  - J Analyte detected below the PQL
  - P Prim./Conf. column %D or RPD exceeds limit
  - B Analyte detected in the associated Method Blank
  - H Holding times for preparation or analysis exceeded
  - ND Not Detected at the Practical Quantitation Limit (PQL)
  - S Spike Recovery outside accepted recovery limits



**Life Science Laboratories, Inc.**  
 5854 Butternut Drive  
 East Syracuse , NY 13057 (315) 445-1900

# Analytical Results

State Certification No: 10248

**CLIENT:** Life Science Labs-LIMS  
**Project:** Jamesville Dewitt Central School Dist.  
**Location:** Tecumseh Elementary School / Lead Study  
**Matrix:** PWS

**Client Sample ID:** TE-021  
**Lab ID:** 2017894-021A  
**Collection Date:** 10/28/20 5:55  
**Date Received:** 10/28/20 13:20

Analyte	Result and Qualifiers	Units	Date Analyzed
<b>METALS BY ICPMS</b>		<b>EPA 200.8,Rev.5.4</b>	<b>(EPA 200.2)</b>
Lead	0.012	mg/L	11/20/20 20:40

- Qualifiers:**
- \* Value may exceed the Acceptable Level
  - E Value exceeds the instrument calibration range
  - J Analyte detected below the PQL
  - P Prim./Conf. column %D or RPD exceeds limit
  - B Analyte detected in the associated Method Blank
  - H Holding times for preparation or analysis exceeded
  - ND Not Detected at the Practical Quantitation Limit (PQL)
  - S Spike Recovery outside accepted recovery limits



**Life Science Laboratories, Inc.**  
 5854 Butternut Drive  
 East Syracuse , NY 13057 (315) 445-1900

# Analytical Results

State Certification No: 10248

**CLIENT:** Life Science Labs-LIMS  
**Project:** Jamesville Dewitt Central School Dist.  
**Location:** Tecumseh Elementary School / Lead Study  
**Matrix:** PWS

**Client Sample ID:** TE-022  
**Lab ID:** 2017894-022A  
**Collection Date:** 10/28/20 5:56  
**Date Received:** 10/28/20 13:20

Analyte	Result and Qualifiers	Units	Date Analyzed
<b>METALS BY ICPMS</b>		<b>EPA 200.8,Rev.5.4</b>	<b>(EPA 200.2)</b>
Lead	0.0094	mg/L	11/20/20 20:42

- Qualifiers:**
- \* Value may exceed the Acceptable Level
  - E Value exceeds the instrument calibration range
  - J Analyte detected below the PQL
  - P Prim./Conf. column %D or RPD exceeds limit
  - B Analyte detected in the associated Method Blank
  - H Holding times for preparation or analysis exceeded
  - ND Not Detected at the Practical Quantitation Limit (PQL)
  - S Spike Recovery outside accepted recovery limits



**Life Science Laboratories, Inc.**  
 5854 Butternut Drive  
 East Syracuse, NY 13057 (315) 445-1900

# Analytical Results

State Certification No: 10248

**CLIENT:** Life Science Labs-LIMS  
**Project:** Jamesville Dewitt Central School Dist.  
**Location:** Tecumseh Elementary School / Lead Study  
**Matrix:** PWS

**Client Sample ID:** TE-023

**Lab ID:** 2017894-023A  
**Collection Date:** 10/28/20 5:57  
**Date Received:** 10/28/20 13:20

Analyte	Result and Qualifiers	Units	Date Analyzed
<b>METALS BY ICPMS</b>		<b>EPA 200.8,Rev.5.4</b>	<b>(EPA 200.2)</b>
Lead	0.0054	mg/L	11/20/20 20:48

- Qualifiers:**
- \* Value may exceed the Acceptable Level
  - E Value exceeds the instrument calibration range
  - J Analyte detected below the PQL
  - P Prim./Conf. column %D or RPD exceeds limit
  - B Analyte detected in the associated Method Blank
  - H Holding times for preparation or analysis exceeded
  - ND Not Detected at the Practical Quantitation Limit (PQL)
  - S Spike Recovery outside accepted recovery limits





**Life Science Laboratories, Inc.**  
 5854 Butternut Drive  
 East Syracuse, NY 13057 (315) 445-1900

# Analytical Results

State Certification No: 10248

**CLIENT:** Life Science Labs-LIMS  
**Project:** Jamesville Dewitt Central School Dist.  
**Location:** Tecumseh Elementary School / Lead Study  
**Matrix:** PWS

**Client Sample ID:** TE-024  
**Lab ID:** 2017894-024A  
**Collection Date:** 10/28/20 5:59  
**Date Received:** 10/28/20 13:20

Analyte	Result and Qualifiers	Units	Date Analyzed
<b>METALS BY ICPMS</b>		<b>EPA 200.8,Rev.5.4</b>	<b>(EPA 200.2)</b>
Lead	0.0025	mg/L	11/20/20 20:50

- Qualifiers:**
- \* Value may exceed the Acceptable Level
  - E Value exceeds the instrument calibration range
  - J Analyte detected below the PQL
  - P Prim./Conf. column %D or RPD exceeds limit
  - B Analyte detected in the associated Method Blank
  - H Holding times for preparation or analysis exceeded
  - ND Not Detected at the Practical Quantitation Limit (PQL)
  - S Spike Recovery outside accepted recovery limits



**Life Science Laboratories, Inc.**  
 5854 Butternut Drive  
 East Syracuse, NY 13057 (315) 445-1900

# Analytical Results

State Certification No: 10248

**CLIENT:** Life Science Labs-LIMS  
**Project:** Jamesville Dewitt Central School Dist.  
**Location:** Tecumseh Elementary School / Lead Study  
**Matrix:** PWS

**Client Sample ID:** TE-025

**Lab ID:** 2017894-025A  
**Collection Date:** 10/28/20 5:59  
**Date Received:** 10/28/20 13:20

Analyte	Result and Qualifiers	Units	Date Analyzed
<b>METALS BY ICPMS</b>		<b>EPA 200.8,Rev.5.4</b>	<b>(EPA 200.2)</b>
Lead	0.0010	mg/L	11/20/20 20:52

- Qualifiers:**
- \* Value may exceed the Acceptable Level
  - E Value exceeds the instrument calibration range
  - J Analyte detected below the PQL
  - P Prim./Conf. column %D or RPD exceeds limit
  - B Analyte detected in the associated Method Blank
  - H Holding times for preparation or analysis exceeded
  - ND Not Detected at the Practical Quantitation Limit (PQL)
  - S Spike Recovery outside accepted recovery limits



**Life Science Laboratories, Inc.**  
 5854 Butternut Drive  
 East Syracuse, NY 13057 (315) 445-1900

# Analytical Results

State Certification No: 10248

**CLIENT:** Life Science Labs-LIMS  
**Project:** Jamesville Dewitt Central School Dist.  
**Location:** Tecumseh Elementary School / Lead Study  
**Matrix:** PWS

**Client Sample ID:** TE-027

**Lab ID:** 2017894-026A  
**Collection Date:** 10/28/20 6:02  
**Date Received:** 10/28/20 13:20

Analyte	Result and Qualifiers	Units	Date Analyzed
<b>METALS BY ICPMS</b>		<b>EPA 200.8,Rev.5.4</b>	<b>(EPA 200.2)</b>
Lead	0.0015	mg/L	11/20/20 20:54

- Qualifiers:**
- \* Value may exceed the Acceptable Level
  - E Value exceeds the instrument calibration range
  - J Analyte detected below the PQL
  - P Prim./Conf. column %D or RPD exceeds limit
  - B Analyte detected in the associated Method Blank
  - H Holding times for preparation or analysis exceeded
  - ND Not Detected at the Practical Quantitation Limit (PQL)
  - S Spike Recovery outside accepted recovery limits



**Life Science Laboratories, Inc.**  
 5854 Butternut Drive  
 East Syracuse , NY 13057 (315) 445-1900

# Analytical Results

State Certification No: 10248

**CLIENT:** Life Science Labs-LIMS  
**Project:** Jamesville Dewitt Central School Dist.  
**Location:** Tecumseh Elementary School / Lead Study  
**Matrix:** PWS

**Client Sample ID:** TE-028  
**Lab ID:** 2017894-027A  
**Collection Date:** 10/28/20 6:03  
**Date Received:** 10/28/20 13:20

Analyte	Result and Qualifiers	Units	Date Analyzed
<b>METALS BY ICPMS</b>		<b>EPA 200.8,Rev.5.4</b>	<b>(EPA 200.2)</b>
Lead	< 0.0010	mg/L	11/20/20 20:56

- Qualifiers:**
- \* Value may exceed the Acceptable Level
  - E Value exceeds the instrument calibration range
  - J Analyte detected below the PQL
  - P Prim./Conf. column %D or RPD exceeds limit
  - B Analyte detected in the associated Method Blank
  - H Holding times for preparation or analysis exceeded
  - ND Not Detected at the Practical Quantitation Limit (PQL)
  - S Spike Recovery outside accepted recovery limits



**Life Science Laboratories, Inc.**  
 5854 Butternut Drive  
 East Syracuse, NY 13057 (315) 445-1900

# Analytical Results

State Certification No: 10248

**CLIENT:** Life Science Labs-LIMS  
**Project:** Jamesville Dewitt Central School Dist.  
**Location:** Tecumseh Elementary School / Lead Study  
**Matrix:** PWS

**Client Sample ID:** TE-029  
**Lab ID:** 2017894-029A  
**Collection Date:** 10/28/20 6:04  
**Date Received:** 10/28/20 13:20

Analyte	Result and Qualifiers	Units	Date Analyzed
<b>METALS BY ICPMS</b>		<b>EPA 200.8,Rev.5.4</b>	<b>(EPA 200.2)</b>
Lead	< 0.0010	mg/L	11/20/20 21:02

**Qualifiers:**

- \* Value may exceed the Acceptable Level
- E Value exceeds the instrument calibration range
- J Analyte detected below the PQL
- P Prim./Conf. column %D or RPD exceeds limit

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Practical Quantitation Limit (PQL)
- S Spike Recovery outside accepted recovery limits



**Life Science Laboratories, Inc.**  
 5854 Butternut Drive  
 East Syracuse, NY 13057 (315) 445-1900

# Analytical Results

State Certification No: 10248

**CLIENT:** Life Science Labs-LIMS  
**Project:** Jamesville Dewitt Central School Dist.  
**Location:** Tecumseh Elementary School / Lead Study  
**Matrix:** PWS

**Client Sample ID:** TE-030

**Lab ID:** 2017894-030A  
**Collection Date:** 10/28/20 6:05  
**Date Received:** 10/28/20 13:20

Analyte	Result and Qualifiers	Units	Date Analyzed
<b>METALS BY ICPMS</b>		<b>EPA 200.8,Rev.5.4</b>	<b>(EPA 200.2)</b>
Lead	0.0015	mg/L	11/20/20 21:04

- Qualifiers:**
- \* Value may exceed the Acceptable Level
  - E Value exceeds the instrument calibration range
  - J Analyte detected below the PQL
  - P Prim./Conf. column %D or RPD exceeds limit
  - B Analyte detected in the associated Method Blank
  - H Holding times for preparation or analysis exceeded
  - ND Not Detected at the Practical Quantitation Limit (PQL)
  - S Spike Recovery outside accepted recovery limits



**Life Science Laboratories, Inc.**  
 5854 Butternut Drive  
 East Syracuse , NY 13057 (315) 445-1900

# Analytical Results

State Certification No: 10248

**CLIENT:** Life Science Labs-LIMS  
**Project:** Jamesville Dewitt Central School Dist.  
**Location:** Tecumseh Elementary School / Lead Study  
**Matrix:** PWS

**Client Sample ID:** *TE-031*  
**Lab ID:** 2017894-031A  
**Collection Date:** 10/28/20 6:10  
**Date Received:** 10/28/20 13:20

Analyte	Result and Qualifiers	Units	Date Analyzed
<b>METALS BY ICPMS</b>		<b>EPA 200.8,Rev.5.4</b>	<b>(EPA 200.2)</b>
Lead	0.0017	mg/L	11/20/20 21:06

- Qualifiers:**
- \* Value may exceed the Acceptable Level
  - E Value exceeds the instrument calibration range
  - J Analyte detected below the PQL
  - P Prim./Conf. column %D or RPD exceeds limit
  - B Analyte detected in the associated Method Blank
  - H Holding times for preparation or analysis exceeded
  - ND Not Detected at the Practical Quantitation Limit (PQL)
  - S Spike Recovery outside accepted recovery limits



**Life Science Laboratories, Inc.**  
 5854 Butternut Drive  
 East Syracuse, NY 13057 (315) 445-1900

# Analytical Results

State Certification No: 10248

**CLIENT:** Life Science Labs-LIMS  
**Project:** Jamesville Dewitt Central School Dist.  
**Location:** Tecumseh Elementary School / Lead Study  
**Matrix:** PWS

**Client Sample ID:** TE-032  
**Lab ID:** 2017894-032A  
**Collection Date:** 10/28/20 6:07  
**Date Received:** 10/28/20 13:20

Analyte	Result and Qualifiers	Units	Date Analyzed
<b>METALS BY ICPMS</b>		<b>EPA 200.8,Rev.5.4</b>	<b>(EPA 200.2)</b>
Lead	0.0011	mg/L	11/20/20 21:08

- Qualifiers:**
- \* Value may exceed the Acceptable Level
  - E Value exceeds the instrument calibration range
  - J Analyte detected below the PQL
  - P Prim./Conf. column %D or RPD exceeds limit
  - B Analyte detected in the associated Method Blank
  - H Holding times for preparation or analysis exceeded
  - ND Not Detected at the Practical Quantitation Limit (PQL)
  - S Spike Recovery outside accepted recovery limits





**Life Science Laboratories, Inc.**  
 5854 Butternut Drive  
 East Syracuse , NY 13057 (315) 445-1900

# Analytical Results

State Certification No: 10248

**CLIENT:** Life Science Labs-LIMS  
**Project:** Jamesville Dewitt Central School Dist.  
**Location:** Tecumseh Elementary School / Lead Study  
**Matrix:** PWS

**Client Sample ID:** TE-034  
**Lab ID:** 2017894-033A  
**Collection Date:** 10/28/20 6:22  
**Date Received:** 10/28/20 13:20

Analyte	Result and Qualifiers	Units	Date Analyzed
<b>METALS BY ICPMS</b>		<b>EPA 200.8,Rev.5.4</b>	<b>(EPA 200.2)</b>
Lead	< 0.0010	mg/L	11/20/20 21:10

- Qualifiers:**
- \* Value may exceed the Acceptable Level
  - E Value exceeds the instrument calibration range
  - J Analyte detected below the PQL
  - P Prim./Conf. column %D or RPD exceeds limit
  - B Analyte detected in the associated Method Blank
  - H Holding times for preparation or analysis exceeded
  - ND Not Detected at the Practical Quantitation Limit (PQL)
  - S Spike Recovery outside accepted recovery limits



**Life Science Laboratories, Inc.**  
 5854 Butternut Drive  
 East Syracuse, NY 13057 (315) 445-1900

# Analytical Results

State Certification No: 10248

**CLIENT:** Life Science Labs-LIMS  
**Project:** Jamesville Dewitt Central School Dist.  
**Location:** Tecumseh Elementary School / Lead Study  
**Matrix:** PWS

**Client Sample ID:** TE-037

**Lab ID:** 2017894-034A  
**Collection Date:** 10/28/20 6:10  
**Date Received:** 10/28/20 13:20

Analyte	Result and Qualifiers	Units	Date Analyzed
<b>METALS BY ICPMS</b>		<b>EPA 200.8,Rev.5.4</b>	<b>(EPA 200.2)</b>
Lead	< 0.0010	mg/L	11/20/20 21:12

- Qualifiers:**
- \* Value may exceed the Acceptable Level
  - E Value exceeds the instrument calibration range
  - J Analyte detected below the PQL
  - P Prim./Conf. column %D or RPD exceeds limit
  - B Analyte detected in the associated Method Blank
  - H Holding times for preparation or analysis exceeded
  - ND Not Detected at the Practical Quantitation Limit (PQL)
  - S Spike Recovery outside accepted recovery limits



**Life Science Laboratories, Inc.**  
 5854 Butternut Drive  
 East Syracuse , NY 13057 (315) 445-1900

# Analytical Results

State Certification No: 10248

**CLIENT:** Life Science Labs-LIMS  
**Project:** Jamesville Dewitt Central School Dist.  
**Location:** Tecumseh Elementary School / Lead Study  
**Matrix:** PWS

**Client Sample ID:** TE-038  
**Lab ID:** 2017894-035A  
**Collection Date:** 10/28/20 6:15  
**Date Received:** 10/28/20 13:20

Analyte	Result and Qualifiers	Units	Date Analyzed
<b>METALS BY ICPMS</b>		<b>EPA 200.8,Rev.5.4</b>	<b>(EPA 200.2)</b>
Lead	< 0.0010	mg/L	11/20/20 21:14

- Qualifiers:**
- \* Value may exceed the Acceptable Level
  - E Value exceeds the instrument calibration range
  - J Analyte detected below the PQL
  - P Prim./Conf. column %D or RPD exceeds limit
  - B Analyte detected in the associated Method Blank
  - H Holding times for preparation or analysis exceeded
  - ND Not Detected at the Practical Quantitation Limit (PQL)
  - S Spike Recovery outside accepted recovery limits



**Life Science Laboratories, Inc.**  
 5854 Butternut Drive  
 East Syracuse , NY 13057 (315) 445-1900

# Analytical Results

State Certification No: 10248

**CLIENT:** Life Science Labs-LIMS  
**Project:** Jamesville Dewitt Central School Dist.  
**Location:** Tecumseh Elementary School / Lead Study  
**Matrix:** PWS

**Client Sample ID:** TE-040  
**Lab ID:** 2017894-036A  
**Collection Date:** 10/28/20 6:15  
**Date Received:** 10/28/20 13:20

Analyte	Result and Qualifiers	Units	Date Analyzed
<b>METALS BY ICPMS</b>		<b>EPA 200.8,Rev.5.4</b>	<b>(EPA 200.2)</b>
Lead	< 0.0010	mg/L	11/20/20 21:16

- Qualifiers:**
- \* Value may exceed the Acceptable Level
  - E Value exceeds the instrument calibration range
  - J Analyte detected below the PQL
  - P Prim./Conf. column %D or RPD exceeds limit
  - B Analyte detected in the associated Method Blank
  - H Holding times for preparation or analysis exceeded
  - ND Not Detected at the Practical Quantitation Limit (PQL)
  - S Spike Recovery outside accepted recovery limits



**Life Science Laboratories, Inc.**  
 5854 Butternut Drive  
 East Syracuse, NY 13057 (315) 445-1900

# Analytical Results

State Certification No: 10248

**CLIENT:** Life Science Labs-LIMS  
**Project:** Jamesville Dewitt Central School Dist.  
**Location:** Tecumseh Elementary School / Lead Study  
**Matrix:** PWS

**Client Sample ID:** TE-041  
**Lab ID:** 2017894-037A  
**Collection Date:** 10/28/20 6:15  
**Date Received:** 10/28/20 13:20

Analyte	Result and Qualifiers	Units	Date Analyzed
<b>METALS BY ICPMS</b>		<b>EPA 200.8,Rev.5.4</b>	<b>(EPA 200.2)</b>
Lead	0.0013	mg/L	11/20/20 21:18

- Qualifiers:**
- \* Value may exceed the Acceptable Level
  - E Value exceeds the instrument calibration range
  - J Analyte detected below the PQL
  - P Prim./Conf. column %D or RPD exceeds limit
  - B Analyte detected in the associated Method Blank
  - H Holding times for preparation or analysis exceeded
  - ND Not Detected at the Practical Quantitation Limit (PQL)
  - S Spike Recovery outside accepted recovery limits



**Life Science Laboratories, Inc.**  
 5854 Butternut Drive  
 East Syracuse , NY 13057 (315) 445-1900

# Analytical Results

State Certification No: 10248

**CLIENT:** Life Science Labs-LIMS  
**Project:** Jamesville Dewitt Central School Dist.  
**Location:** Tecumseh Elementary School / Lead Study  
**Matrix:** PWS

**Client Sample ID:** TE-042  
**Lab ID:** 2017894-038A  
**Collection Date:** 10/28/20 6:16  
**Date Received:** 10/28/20 13:20

Analyte	Result and Qualifiers	Units	Date Analyzed
<b>METALS BY ICPMS</b>		<b>EPA 200.8,Rev.5.4</b>	<b>(EPA 200.2)</b>
Lead	< 0.0010	mg/L	11/20/20 21:20

- Qualifiers:**
- \* Value may exceed the Acceptable Level
  - E Value exceeds the instrument calibration range
  - J Analyte detected below the PQL
  - P Prim./Conf. column %D or RPD exceeds limit
  - B Analyte detected in the associated Method Blank
  - H Holding times for preparation or analysis exceeded
  - ND Not Detected at the Practical Quantitation Limit (PQL)
  - S Spike Recovery outside accepted recovery limits



**Life Science Laboratories, Inc.**  
 5854 Butternut Drive  
 East Syracuse , NY 13057 (315) 445-1900

# Analytical Results

State Certification No: 10248

**CLIENT:** Life Science Labs-LIMS  
**Project:** Jamesville Dewitt Central School Dist.  
**Location:** Tecumseh Elementary School / Lead Study  
**Matrix:** PWS

**Client Sample ID:** TE-043  
**Lab ID:** 2017894-039A  
**Collection Date:** 10/28/20 6:17  
**Date Received:** 10/28/20 13:20

Analyte	Result and Qualifiers	Units	Date Analyzed
<b>METALS BY ICPMS</b>		<b>EPA 200.8,Rev.5.4</b>	<b>(EPA 200.2)</b>
Lead	0.0022	mg/L	11/20/20 21:26

- Qualifiers:**
- \* Value may exceed the Acceptable Level
  - E Value exceeds the instrument calibration range
  - J Analyte detected below the PQL
  - P Prim./Conf. column %D or RPD exceeds limit
  - B Analyte detected in the associated Method Blank
  - H Holding times for preparation or analysis exceeded
  - ND Not Detected at the Practical Quantitation Limit (PQL)
  - S Spike Recovery outside accepted recovery limits



**Life Science Laboratories, Inc.**  
 5854 Butternut Drive  
 East Syracuse, NY 13057 (315) 445-1900

# Analytical Results

State Certification No: 10248

**CLIENT:** Life Science Labs-LIMS  
**Project:** Jamesville Dewitt Central School Dist.  
**Location:** Tecumseh Elementary School / Lead Study  
**Matrix:** PWS

**Client Sample ID:** TE-045

**Lab ID:** 2017894-040A  
**Collection Date:** 10/28/20 6:17  
**Date Received:** 10/28/20 13:20

Analyte	Result and Qualifiers	Units	Date Analyzed
<b>METALS BY ICPMS</b>		<b>EPA 200.8,Rev.5.4</b>	<b>(EPA 200.2)</b>
Lead	0.0043	mg/L	11/20/20 21:28

- Qualifiers:**
- \* Value may exceed the Acceptable Level
  - E Value exceeds the instrument calibration range
  - J Analyte detected below the PQL
  - P Prim./Conf. column %D or RPD exceeds limit
  - B Analyte detected in the associated Method Blank
  - H Holding times for preparation or analysis exceeded
  - ND Not Detected at the Practical Quantitation Limit (PQL)
  - S Spike Recovery outside accepted recovery limits





**Life Science Laboratories, Inc.**  
 5854 Butternut Drive  
 East Syracuse , NY 13057 (315) 445-1900

# Analytical Results

State Certification No: 10248

**CLIENT:** Life Science Labs-LIMS  
**Project:** Jamesville Dewitt Central School Dist.  
**Location:** Tecumseh Elementary School / Lead Study  
**Matrix:** PWS

**Client Sample ID:** TE-046  
**Lab ID:** 2017894-041A  
**Collection Date:** 10/28/20 6:18  
**Date Received:** 10/28/20 13:20

Analyte	Result and Qualifiers	Units	Date Analyzed
<b>METALS BY ICPMS</b>		<b>EPA 200.8,Rev.5.4</b>	<b>(EPA 200.2)</b>
Lead	0.0041	mg/L	11/20/20 21:30

- Qualifiers:**
- \* Value may exceed the Acceptable Level
  - E Value exceeds the instrument calibration range
  - J Analyte detected below the PQL
  - P Prim./Conf. column %D or RPD exceeds limit
  - B Analyte detected in the associated Method Blank
  - H Holding times for preparation or analysis exceeded
  - ND Not Detected at the Practical Quantitation Limit (PQL)
  - S Spike Recovery outside accepted recovery limits



**Life Science Laboratories, Inc.**  
 5854 Butternut Drive  
 East Syracuse , NY 13057 (315) 445-1900

# Analytical Results

State Certification No: 10248

**CLIENT:** Life Science Labs-LIMS  
**Project:** Jamesville Dewitt Central School Dist.  
**Location:** Tecumseh Elementary School / Lead Study  
**Matrix:** PWS

**Client Sample ID:** TE-047

**Lab ID:** 2017894-042A  
**Collection Date:** 10/28/20 6:20  
**Date Received:** 10/28/20 13:20

Analyte	Result and Qualifiers	Units	Date Analyzed
<b>METALS BY ICPMS</b>		<b>EPA 200.8,Rev.5.4</b>	<b>(EPA 200.2)</b>
Lead	0.0055	mg/L	11/20/20 21:32

**Qualifiers:**

- \* Value may exceed the Acceptable Level
- E Value exceeds the instrument calibration range
- J Analyte detected below the PQL
- P Prim./Conf. column %D or RPD exceeds limit

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Practical Quantitation Limit (PQL)
- S Spike Recovery outside accepted recovery limits



**Life Science Laboratories, Inc.**  
 5854 Butternut Drive  
 East Syracuse, NY 13057 (315) 445-1900

# Analytical Results

State Certification No: 10248

**CLIENT:** Life Science Labs-LIMS  
**Project:** Jamesville Dewitt Central School Dist.  
**Location:** Tecumseh Elementary School / Lead Study  
**Matrix:** PWS

**Client Sample ID:** TE-048

**Lab ID:** 2017894-043A  
**Collection Date:** 10/28/20 6:20  
**Date Received:** 10/28/20 13:20

Analyte	Result and Qualifiers	Units	Date Analyzed
<b>METALS BY ICPMS</b>		<b>EPA 200.8,Rev.5.4</b>	<b>(EPA 200.2)</b>
Lead	0.0016	mg/L	11/18/20 19:26

**Qualifiers:**

- \* Value may exceed the Acceptable Level
- E Value exceeds the instrument calibration range
- J Analyte detected below the PQL
- P Prim./Conf. column %D or RPD exceeds limit

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Practical Quantitation Limit (PQL)
- S Spike Recovery outside accepted recovery limits



**Life Science Laboratories, Inc.**  
 5854 Butternut Drive  
 East Syracuse , NY 13057 (315) 445-1900

# Analytical Results

State Certification No: 10248

**CLIENT:** Life Science Labs-LIMS  
**Project:** Jamesville Dewitt Central School Dist.  
**Location:** Tecumseh Elementary School / Lead Study  
**Matrix:** PWS

**Client Sample ID:** TE-049  
**Lab ID:** 2017894-044A  
**Collection Date:** 10/28/20 6:22  
**Date Received:** 10/28/20 13:20

Analyte	Result and Qualifiers	Units	Date Analyzed
<b>METALS BY ICPMS</b>		<b>EPA 200.8,Rev.5.4</b>	<b>(EPA 200.2)</b>
Lead	0.0022	mg/L	11/18/20 19:32

- Qualifiers:**
- \* Value may exceed the Acceptable Level
  - E Value exceeds the instrument calibration range
  - J Analyte detected below the PQL
  - P Prim./Conf. column %D or RPD exceeds limit
  - B Analyte detected in the associated Method Blank
  - H Holding times for preparation or analysis exceeded
  - ND Not Detected at the Practical Quantitation Limit (PQL)
  - S Spike Recovery outside accepted recovery limits



**Life Science Laboratories, Inc.**  
 5854 Butternut Drive  
 East Syracuse , NY 13057 (315) 445-1900

# Analytical Results

State Certification No: 10248

**CLIENT:** Life Science Labs-LIMS  
**Project:** Jamesville Dewitt Central School Dist.  
**Location:** Tecumseh Elementary School / Lead Study  
**Matrix:** PWS

**Client Sample ID:** TE-051  
**Lab ID:** 2017894-045A  
**Collection Date:** 10/28/20 6:18  
**Date Received:** 10/28/20 13:20

Analyte	Result and Qualifiers	Units	Date Analyzed
<b>METALS BY ICPMS</b>		<b>EPA 200.8,Rev.5.4</b>	<b>(EPA 200.2)</b>
Lead	0.0032	mg/L	11/18/20 19:38

- Qualifiers:**
- \* Value may exceed the Acceptable Level
  - E Value exceeds the instrument calibration range
  - J Analyte detected below the PQL
  - P Prim./Conf. column %D or RPD exceeds limit
  - B Analyte detected in the associated Method Blank
  - H Holding times for preparation or analysis exceeded
  - ND Not Detected at the Practical Quantitation Limit (PQL)
  - S Spike Recovery outside accepted recovery limits



**Life Science Laboratories, Inc.**  
 5854 Butternut Drive  
 East Syracuse , NY 13057 (315) 445-1900

# Analytical Results

State Certification No: 10248

**CLIENT:** Life Science Labs-LIMS  
**Project:** Jamesville Dewitt Central School Dist.  
**Location:** Tecumseh Elementary School / Lead Study  
**Matrix:** PWS

**Client Sample ID:** TE-052  
**Lab ID:** 2017894-046A  
**Collection Date:** 10/28/20 6:20  
**Date Received:** 10/28/20 13:20

Analyte	Result and Qualifiers	Units	Date Analyzed
<b>METALS BY ICPMS</b>		<b>EPA 200.8,Rev.5.4</b>	<b>(EPA 200.2)</b>
Lead	0.0018	mg/L	11/18/20 19:40

- Qualifiers:**
- \* Value may exceed the Acceptable Level
  - E Value exceeds the instrument calibration range
  - J Analyte detected below the PQL
  - P Prim./Conf. column %D or RPD exceeds limit
  - B Analyte detected in the associated Method Blank
  - H Holding times for preparation or analysis exceeded
  - ND Not Detected at the Practical Quantitation Limit (PQL)
  - S Spike Recovery outside accepted recovery limits



**Life Science Laboratories, Inc.**  
 5854 Butternut Drive  
 East Syracuse, NY 13057 (315) 445-1900

# Analytical Results

State Certification No: 10248

**CLIENT:** Life Science Labs-LIMS  
**Project:** Jamesville Dewitt Central School Dist.  
**Location:** Tecumseh Elementary School / Lead Study  
**Matrix:** PWS

**Client Sample ID:** TE-091  
**Lab ID:** 2017894-047A  
**Collection Date:** 10/28/20 8:00  
**Date Received:** 10/28/20 13:20

Analyte	Result and Qualifiers	Units	Date Analyzed
<b>METALS BY ICPMS</b>		<b>EPA 200.8,Rev.5.4</b>	<b>(EPA 200.2)</b>
Lead	0.0075	mg/L	11/18/20 19:42

- Qualifiers:**
- \* Value may exceed the Acceptable Level
  - E Value exceeds the instrument calibration range
  - J Analyte detected below the PQL
  - P Prim./Conf. column %D or RPD exceeds limit
  - B Analyte detected in the associated Method Blank
  - H Holding times for preparation or analysis exceeded
  - ND Not Detected at the Practical Quantitation Limit (PQL)
  - S Spike Recovery outside accepted recovery limits



**Life Science Laboratories, Inc.**  
 5854 Butternut Drive  
 East Syracuse , NY 13057 (315) 445-1900

# Analytical Results

State Certification No: 10248

**CLIENT:** Life Science Labs-LIMS  
**Project:** Jamesville Dewitt Central School Dist.  
**Location:** Tecumseh Elementary School / Lead Study  
**Matrix:** PWS

**Client Sample ID:** TE-053  
**Lab ID:** 2017894-048A  
**Collection Date:** 10/28/20 6:18  
**Date Received:** 10/28/20 13:20

Analyte	Result and Qualifiers	Units	Date Analyzed
<b>METALS BY ICPMS</b>		<b>EPA 200.8,Rev.5.4</b>	<b>(EPA 200.2)</b>
Lead	0.0046	mg/L	11/18/20 19:44

- Qualifiers:**
- \* Value may exceed the Acceptable Level
  - E Value exceeds the instrument calibration range
  - J Analyte detected below the PQL
  - P Prim./Conf. column %D or RPD exceeds limit
  - B Analyte detected in the associated Method Blank
  - H Holding times for preparation or analysis exceeded
  - ND Not Detected at the Practical Quantitation Limit (PQL)
  - S Spike Recovery outside accepted recovery limits





**Life Science Laboratories, Inc.**  
 5854 Butternut Drive  
 East Syracuse , NY 13057 (315) 445-1900

# Analytical Results

State Certification No: 10248

**CLIENT:** Life Science Labs-LIMS  
**Project:** Jamesville Dewitt Central School Dist.  
**Location:** Tecumseh Elementary School / Lead Study  
**Matrix:** PWS

**Client Sample ID:** TE-054  
**Lab ID:** 2017894-049A  
**Collection Date:** 10/28/20 6:17  
**Date Received:** 10/28/20 13:20

Analyte	Result and Qualifiers	Units	Date Analyzed
<b>METALS BY ICPMS</b>		<b>EPA 200.8,Rev.5.4</b>	<b>(EPA 200.2)</b>
Lead	0.0014	mg/L	11/18/20 19:46

- Qualifiers:**
- \* Value may exceed the Acceptable Level
  - E Value exceeds the instrument calibration range
  - J Analyte detected below the PQL
  - P Prim./Conf. column %D or RPD exceeds limit
  - B Analyte detected in the associated Method Blank
  - H Holding times for preparation or analysis exceeded
  - ND Not Detected at the Practical Quantitation Limit (PQL)
  - S Spike Recovery outside accepted recovery limits



**Life Science Laboratories, Inc.**  
 5854 Butternut Drive  
 East Syracuse, NY 13057 (315) 445-1900

# Analytical Results

State Certification No: 10248

**CLIENT:** Life Science Labs-LIMS  
**Project:** Jamesville Dewitt Central School Dist.  
**Location:** Tecumseh Elementary School / Lead Study  
**Matrix:** PWS

**Client Sample ID:** TE-055  
**Lab ID:** 2017894-050A  
**Collection Date:** 10/28/20 6:20  
**Date Received:** 10/28/20 13:20

Analyte	Result and Qualifiers	Units	Date Analyzed
<b>METALS BY ICPMS</b>		<b>EPA 200.8,Rev.5.4</b>	<b>(EPA 200.2)</b>
Lead	< 0.0010	mg/L	11/18/20 19:48

- Qualifiers:**
- \* Value may exceed the Acceptable Level
  - E Value exceeds the instrument calibration range
  - J Analyte detected below the PQL
  - P Prim./Conf. column %D or RPD exceeds limit
  - B Analyte detected in the associated Method Blank
  - H Holding times for preparation or analysis exceeded
  - ND Not Detected at the Practical Quantitation Limit (PQL)
  - S Spike Recovery outside accepted recovery limits



**Life Science Laboratories, Inc.**  
 5854 Butternut Drive  
 East Syracuse , NY 13057 (315) 445-1900

# Analytical Results

State Certification No: 10248

**CLIENT:** Life Science Labs-LIMS  
**Project:** Jamesville Dewitt Central School Dist.  
**Location:** Tecumseh Elementary School / Lead Study  
**Matrix:** PWS

**Client Sample ID:** TE-059  
**Lab ID:** 2017894-052A  
**Collection Date:** 10/28/20 6:20  
**Date Received:** 10/28/20 13:20

Analyte	Result and Qualifiers	Units	Date Analyzed
<b>METALS BY ICPMS</b>		<b>EPA 200.8,Rev.5.4</b>	<b>(EPA 200.2)</b>
Lead	0.0054	mg/L	11/25/20 12:05

- Qualifiers:**
- \* Value may exceed the Acceptable Level
  - E Value exceeds the instrument calibration range
  - J Analyte detected below the PQL
  - P Prim./Conf. column %D or RPD exceeds limit
  - B Analyte detected in the associated Method Blank
  - H Holding times for preparation or analysis exceeded
  - ND Not Detected at the Practical Quantitation Limit (PQL)
  - S Spike Recovery outside accepted recovery limits



**Life Science Laboratories, Inc.**  
 5854 Butternut Drive  
 East Syracuse , NY 13057 (315) 445-1900

# Analytical Results

State Certification No: 10248

**CLIENT:** Life Science Labs-LIMS  
**Project:** Jamesville Dewitt Central School Dist.  
**Location:** Tecumseh Elementary School / Lead Study  
**Matrix:** PWS

**Client Sample ID:** TE-057  
**Lab ID:** 2017894-053A  
**Collection Date:** 10/28/20 6:20  
**Date Received:** 10/28/20 13:20

Analyte	Result and Qualifiers	Units	Date Analyzed
<b>METALS BY ICPMS</b>		<b>EPA 200.8,Rev.5.4</b>	<b>(EPA 200.2)</b>
Lead	0.0086	mg/L	11/25/20 12:12

- Qualifiers:**
- \* Value may exceed the Acceptable Level
  - E Value exceeds the instrument calibration range
  - J Analyte detected below the PQL
  - P Prim./Conf. column %D or RPD exceeds limit
  - B Analyte detected in the associated Method Blank
  - H Holding times for preparation or analysis exceeded
  - ND Not Detected at the Practical Quantitation Limit (PQL)
  - S Spike Recovery outside accepted recovery limits



**Life Science Laboratories, Inc.**  
 5854 Butternut Drive  
 East Syracuse , NY 13057 (315) 445-1900

# Analytical Results

State Certification No: 10248

**CLIENT:** Life Science Labs-LIMS  
**Project:** Jamesville Dewitt Central School Dist.  
**Location:** Tecumseh Elementary School / Lead Study  
**Matrix:** PWS

**Client Sample ID:** TE-061  
**Lab ID:** 2017894-054A  
**Collection Date:** 10/28/20 6:40  
**Date Received:** 10/28/20 13:20

Analyte	Result and Qualifiers	Units	Date Analyzed
<b>METALS BY ICPMS</b>		<b>EPA 200.8,Rev.5.4</b>	<b>(EPA 200.2)</b>
Lead	0.0095	mg/L	11/25/20 12:11

- Qualifiers:**
- \* Value may exceed the Acceptable Level
  - E Value exceeds the instrument calibration range
  - J Analyte detected below the PQL
  - P Prim./Conf. column %D or RPD exceeds limit
  - B Analyte detected in the associated Method Blank
  - H Holding times for preparation or analysis exceeded
  - ND Not Detected at the Practical Quantitation Limit (PQL)
  - S Spike Recovery outside accepted recovery limits



**Life Science Laboratories, Inc.**  
 5854 Butternut Drive  
 East Syracuse , NY 13057 (315) 445-1900

# Analytical Results

State Certification No: 10248

**CLIENT:** Life Science Labs-LIMS  
**Project:** Jamesville Dewitt Central School Dist.  
**Location:** Tecumseh Elementary School / Lead Study  
**Matrix:** PWS

**Client Sample ID:** *TE-060*  
**Lab ID:** 2017894-055A  
**Collection Date:** 10/18/20 6:30  
**Date Received:** 10/28/20 13:20

Analyte	Result and Qualifiers	Units	Date Analyzed
<b>METALS BY ICPMS</b>		<b>EPA 200.8,Rev.5.4</b>	<b>(EPA 200.2)</b>
Lead	0.0013	mg/L	11/18/20 19:50

- Qualifiers:**
- \* Value may exceed the Acceptable Level
  - E Value exceeds the instrument calibration range
  - J Analyte detected below the PQL
  - P Prim./Conf. column %D or RPD exceeds limit
  - B Analyte detected in the associated Method Blank
  - H Holding times for preparation or analysis exceeded
  - ND Not Detected at the Practical Quantitation Limit (PQL)
  - S Spike Recovery outside accepted recovery limits



**Life Science Laboratories, Inc.**  
 5854 Butternut Drive  
 East Syracuse , NY 13057 (315) 445-1900

# Analytical Results

State Certification No: 10248

**CLIENT:** Life Science Labs-LIMS  
**Project:** Jamesville Dewitt Central School Dist.  
**Location:** Tecumseh Elementary School / Lead Study  
**Matrix:** PWS

**Client Sample ID:** TE-062  
**Lab ID:** 2017894-056A  
**Collection Date:** 10/18/20 6:50  
**Date Received:** 10/28/20 13:20

Analyte	Result and Qualifiers	Units	Date Analyzed
<b>METALS BY ICPMS</b>		<b>EPA 200.8,Rev.5.4</b>	<b>(EPA 200.2)</b>
Lead	0.0047	mg/L	11/18/20 19:52

- Qualifiers:**
- \* Value may exceed the Acceptable Level
  - E Value exceeds the instrument calibration range
  - J Analyte detected below the PQL
  - P Prim./Conf. column %D or RPD exceeds limit
  - B Analyte detected in the associated Method Blank
  - H Holding times for preparation or analysis exceeded
  - ND Not Detected at the Practical Quantitation Limit (PQL)
  - S Spike Recovery outside accepted recovery limits



**Life Science Laboratories, Inc.**  
 5854 Butternut Drive  
 East Syracuse, NY 13057 (315) 445-1900

# Analytical Results

State Certification No: 10248

**CLIENT:** Life Science Labs-LIMS  
**Project:** Jamesville Dewitt Central School Dist.  
**Location:** Tecumseh Elementary School / Lead Study  
**Matrix:** PWS

**Client Sample ID:** TE-063

**Lab ID:** 2017894-057A  
**Collection Date:** 10/18/20 6:50  
**Date Received:** 10/28/20 13:20

Analyte	Result and Qualifiers	Units	Date Analyzed
<b>METALS BY ICPMS</b>		<b>EPA 200.8,Rev.5.4</b>	<b>(EPA 200.2)</b>
Lead	0.0026	mg/L	11/18/20 19:54

**Qualifiers:**

- \* Value may exceed the Acceptable Level
- E Value exceeds the instrument calibration range
- J Analyte detected below the PQL
- P Prim./Conf. column %D or RPD exceeds limit

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Practical Quantitation Limit (PQL)
- S Spike Recovery outside accepted recovery limits





**Life Science Laboratories, Inc.**  
 5854 Butternut Drive  
 East Syracuse, NY 13057 (315) 445-1900

# Analytical Results

State Certification No: 10248

**CLIENT:** Life Science Labs-LIMS  
**Project:** Jamesville Dewitt Central School Dist.  
**Location:** Tecumseh Elementary School / Lead Study  
**Matrix:** PWS

**Client Sample ID:** TE-064  
**Lab ID:** 2017894-058A  
**Collection Date:** 10/18/20 6:55  
**Date Received:** 10/28/20 13:20

Analyte	Result and Qualifiers	Units	Date Analyzed
<b>METALS BY ICPMS</b>		<b>EPA 200.8,Rev.5.4</b>	<b>(EPA 200.2)</b>
Lead	0.0033	mg/L	11/18/20 19:56

- Qualifiers:**
- \* Value may exceed the Acceptable Level
  - E Value exceeds the instrument calibration range
  - J Analyte detected below the PQL
  - P Prim./Conf. column %D or RPD exceeds limit
  - B Analyte detected in the associated Method Blank
  - H Holding times for preparation or analysis exceeded
  - ND Not Detected at the Practical Quantitation Limit (PQL)
  - S Spike Recovery outside accepted recovery limits



**Life Science Laboratories, Inc.**  
 5854 Butternut Drive  
 East Syracuse , NY 13057 (315) 445-1900

# Analytical Results

State Certification No: 10248

**CLIENT:** Life Science Labs-LIMS  
**Project:** Jamesville Dewitt Central School Dist.  
**Location:** Tecumseh Elementary School / Lead Study  
**Matrix:** PWS

**Client Sample ID:** TE-065

**Lab ID:** 2017894-059A  
**Collection Date:** 10/18/20 6:58  
**Date Received:** 10/28/20 13:20

Analyte	Result and Qualifiers	Units	Date Analyzed
<b>METALS BY ICPMS</b>		<b>EPA 200.8,Rev.5.4</b>	<b>(EPA 200.2)</b>
Lead	0.0033	mg/L	11/18/20 20:02

- Qualifiers:**
- \* Value may exceed the Acceptable Level
  - E Value exceeds the instrument calibration range
  - J Analyte detected below the PQL
  - P Prim./Conf. column %D or RPD exceeds limit
  - B Analyte detected in the associated Method Blank
  - H Holding times for preparation or analysis exceeded
  - ND Not Detected at the Practical Quantitation Limit (PQL)
  - S Spike Recovery outside accepted recovery limits



**Life Science Laboratories, Inc.**  
 5854 Butternut Drive  
 East Syracuse , NY 13057 (315) 445-1900

# Analytical Results

State Certification No: 10248

**CLIENT:** Life Science Labs-LIMS  
**Project:** Jamesville Dewitt Central School Dist.  
**Location:** Tecumseh Elementary School / Lead Study  
**Matrix:** PWS

**Client Sample ID:** TE- 067

**Lab ID:** 2017894-060A  
**Collection Date:** 10/18/20 7:05  
**Date Received:** 10/28/20 13:20

Analyte	Result and Qualifiers	Units	Date Analyzed
<b>METALS BY ICPMS</b>		<b>EPA 200.8,Rev.5.4</b>	<b>(EPA 200.2)</b>
Lead	< 0.0010	mg/L	11/18/20 20:04

- Qualifiers:**
- \* Value may exceed the Acceptable Level
  - E Value exceeds the instrument calibration range
  - J Analyte detected below the PQL
  - P Prim./Conf. column %D or RPD exceeds limit
  - B Analyte detected in the associated Method Blank
  - H Holding times for preparation or analysis exceeded
  - ND Not Detected at the Practical Quantitation Limit (PQL)
  - S Spike Recovery outside accepted recovery limits



**Life Science Laboratories, Inc.**  
 5854 Butternut Drive  
 East Syracuse , NY 13057 (315) 445-1900

# Analytical Results

State Certification No: 10248

**CLIENT:** Life Science Labs-LIMS  
**Project:** Jamesville Dewitt Central School Dist.  
**Location:** Tecumseh Elementary School / Lead Study  
**Matrix:** PWS

**Client Sample ID:** TE-066  
**Lab ID:** 2017894-061A  
**Collection Date:** 10/18/20 7:00  
**Date Received:** 10/28/20 13:20

Analyte	Result and Qualifiers	Units	Date Analyzed
<b>METALS BY ICPMS</b>		<b>EPA 200.8,Rev.5.4</b>	<b>(EPA 200.2)</b>
Lead	< 0.0010	mg/L	11/18/20 20:06

- Qualifiers:**
- \* Value may exceed the Acceptable Level
  - E Value exceeds the instrument calibration range
  - J Analyte detected below the PQL
  - P Prim./Conf. column %D or RPD exceeds limit
  - B Analyte detected in the associated Method Blank
  - H Holding times for preparation or analysis exceeded
  - ND Not Detected at the Practical Quantitation Limit (PQL)
  - S Spike Recovery outside accepted recovery limits



**Life Science Laboratories, Inc.**  
 5854 Butternut Drive  
 East Syracuse , NY 13057 (315) 445-1900

# Analytical Results

State Certification No: 10248

**CLIENT:** Life Science Labs-LIMS  
**Project:** Jamesville Dewitt Central School Dist.  
**Location:** Tecumseh Elementary School / Lead Study  
**Matrix:** PWS

**Client Sample ID:** TE-069  
**Lab ID:** 2017894-062A  
**Collection Date:** 10/18/20 7:15  
**Date Received:** 10/28/20 13:20

Analyte	Result and Qualifiers	Units	Date Analyzed
<b>METALS BY ICPMS</b>		<b>EPA 200.8,Rev.5.4</b>	<b>(EPA 200.2)</b>
Lead	0.0017	mg/L	11/18/20 20:08

- Qualifiers:**
- \* Value may exceed the Acceptable Level
  - E Value exceeds the instrument calibration range
  - J Analyte detected below the PQL
  - P Prim./Conf. column %D or RPD exceeds limit
  - B Analyte detected in the associated Method Blank
  - H Holding times for preparation or analysis exceeded
  - ND Not Detected at the Practical Quantitation Limit (PQL)
  - S Spike Recovery outside accepted recovery limits



**Life Science Laboratories, Inc.**  
 5854 Butternut Drive  
 East Syracuse , NY 13057 (315) 445-1900

# Analytical Results

State Certification No: 10248

**CLIENT:** Life Science Labs-LIMS  
**Project:** Jamesville Dewitt Central School Dist.  
**Location:** Tecumseh Elementary School / Lead Study  
**Matrix:** PWS

**Client Sample ID:** TE-070

**Lab ID:** 2017894-063A  
**Collection Date:** 10/18/20 7:15  
**Date Received:** 10/28/20 13:20

Analyte	Result and Qualifiers	Units	Date Analyzed
<b>METALS BY ICPMS</b>		<b>EPA 200.8,Rev.5.4</b>	<b>(EPA 200.2)</b>
Lead	< 0.0010	mg/L	11/18/20 20:10

**Qualifiers:**

- \* Value may exceed the Acceptable Level
- E Value exceeds the instrument calibration range
- J Analyte detected below the PQL
- P Prim./Conf. column %D or RPD exceeds limit

- B Analyte detected in the associated Method Blank
- H Holding times for preparation or analysis exceeded
- ND Not Detected at the Practical Quantitation Limit (PQL)
- S Spike Recovery outside accepted recovery limits



**Life Science Laboratories, Inc.**  
 5854 Butternut Drive  
 East Syracuse , NY 13057 (315) 445-1900

# Analytical Results

State Certification No: 10248

**CLIENT:** Life Science Labs-LIMS  
**Project:** Jamesville Dewitt Central School Dist.  
**Location:** Tecumseh Elementary School / Lead Study  
**Matrix:** PWS

**Client Sample ID:** TE-071  
**Lab ID:** 2017894-064A  
**Collection Date:** 10/18/20 7:18  
**Date Received:** 10/28/20 13:20

Analyte	Result and Qualifiers	Units	Date Analyzed
<b>METALS BY ICPMS</b>		<b>EPA 200.8,Rev.5.4</b>	<b>(EPA 200.2)</b>
Lead	< 0.0010	mg/L	11/18/20 20:12

- Qualifiers:**
- \* Value may exceed the Acceptable Level
  - E Value exceeds the instrument calibration range
  - J Analyte detected below the PQL
  - P Prim./Conf. column %D or RPD exceeds limit
  - B Analyte detected in the associated Method Blank
  - H Holding times for preparation or analysis exceeded
  - ND Not Detected at the Practical Quantitation Limit (PQL)
  - S Spike Recovery outside accepted recovery limits



**Life Science Laboratories, Inc.**  
 5854 Butternut Drive  
 East Syracuse, NY 13057 (315) 445-1900

# Analytical Results

State Certification No: 10248

**CLIENT:** Life Science Labs-LIMS  
**Project:** Jamesville Dewitt Central School Dist.  
**Location:** Tecumseh Elementary School / Lead Study  
**Matrix:** PWS

**Client Sample ID:** TE-073  
**Lab ID:** 2017894-065A  
**Collection Date:** 10/18/20 7:20  
**Date Received:** 10/28/20 13:20

Analyte	Result and Qualifiers	Units	Date Analyzed
<b>METALS BY ICPMS</b>		<b>EPA 200.8, Rev. 5.4</b>	<b>(EPA 200.2)</b>
Lead	< 0.0010	mg/L	11/18/20 20:14

- Qualifiers:**
- \* Value may exceed the Acceptable Level
  - E Value exceeds the instrument calibration range
  - J Analyte detected below the PQL
  - P Prim./Conf. column %D or RPD exceeds limit
  - B Analyte detected in the associated Method Blank
  - H Holding times for preparation or analysis exceeded
  - ND Not Detected at the Practical Quantitation Limit (PQL)
  - S Spike Recovery outside accepted recovery limits





**Life Science Laboratories, Inc.**  
 5854 Butternut Drive  
 East Syracuse , NY 13057 (315) 445-1900

# Analytical Results

State Certification No: 10248

**CLIENT:** Life Science Labs-LIMS  
**Project:** Jamesville Dewitt Central School Dist.  
**Location:** Tecumseh Elementary School / Lead Study  
**Matrix:** PWS

**Client Sample ID:** TE-068  
**Lab ID:** 2017894-066A  
**Collection Date:** 10/18/20 7:16  
**Date Received:** 10/28/20 13:20

Analyte	Result and Qualifiers	Units	Date Analyzed
<b>METALS BY ICPMS</b>		<b>EPA 200.8,Rev.5.4</b>	<b>(EPA 200.2)</b>
Lead	0.0022	mg/L	11/18/20 20:16

- Qualifiers:**
- \* Value may exceed the Acceptable Level
  - E Value exceeds the instrument calibration range
  - J Analyte detected below the PQL
  - P Prim./Conf. column %D or RPD exceeds limit
  - B Analyte detected in the associated Method Blank
  - H Holding times for preparation or analysis exceeded
  - ND Not Detected at the Practical Quantitation Limit (PQL)
  - S Spike Recovery outside accepted recovery limits



**Life Science Laboratories, Inc.**  
 5854 Butternut Drive  
 East Syracuse , NY 13057 (315) 445-1900

# Analytical Results

State Certification No: 10248

**CLIENT:** Life Science Labs-LIMS  
**Project:** Jamesville Dewitt Central School Dist.  
**Location:** Tecumseh Elementary School / Lead Study  
**Matrix:** PWS

**Client Sample ID:** TE-050  
**Lab ID:** 2017894-067A  
**Collection Date:** 10/18/20 6:23  
**Date Received:** 10/28/20 13:20

Analyte	Result and Qualifiers	Units	Date Analyzed
<b>METALS BY ICPMS</b>		<b>EPA 200.8,Rev.5.4</b>	<b>(EPA 200.2)</b>
Lead	0.0013	mg/L	11/18/20 20:18

- Qualifiers:**
- \* Value may exceed the Acceptable Level
  - E Value exceeds the instrument calibration range
  - J Analyte detected below the PQL
  - P Prim./Conf. column %D or RPD exceeds limit
  - B Analyte detected in the associated Method Blank
  - H Holding times for preparation or analysis exceeded
  - ND Not Detected at the Practical Quantitation Limit (PQL)
  - S Spike Recovery outside accepted recovery limits



**Life Science Laboratories, Inc.**  
 5854 Butternut Drive  
 East Syracuse , NY 13057 (315) 445-1900

# Analytical Results

State Certification No: 10248

**CLIENT:** Life Science Labs-LIMS  
**Project:** Jamesville Dewitt Central School Dist.  
**Location:** Tecumseh Elementary School / Lead Study  
**Matrix:** PWS

**Client Sample ID:** TE-056  
**Lab ID:** 2017894-068A  
**Collection Date:** 10/18/20 6:30  
**Date Received:** 10/28/20 13:20

Analyte	Result and Qualifiers	Units	Date Analyzed
<b>METALS BY ICPMS</b>		<b>EPA 200.8,Rev.5.4</b>	<b>(EPA 200.2)</b>
Lead	< 0.0010	mg/L	11/18/20 20:28

- Qualifiers:**
- \* Value may exceed the Acceptable Level
  - E Value exceeds the instrument calibration range
  - J Analyte detected below the PQL
  - P Prim./Conf. column %D or RPD exceeds limit
  - B Analyte detected in the associated Method Blank
  - H Holding times for preparation or analysis exceeded
  - ND Not Detected at the Practical Quantitation Limit (PQL)
  - S Spike Recovery outside accepted recovery limits



Life Science Laboratories, Inc.

5854 Butternut Drive  
East Syracuse, NY 13057

Phone # (315) 445-1900

Telefax # (315) 445-1104

### Chain of Custody Record

2017894

JamesvilleDewittCSD

7630

Client: Tecumseh Elementary School Phone # 315-445-8320  
Address: 901 Nottingham Road Fax # 315-445-9872  
Jamesville, NY 13078

Contact Person: \_\_\_\_\_ LSL Project #: \_\_\_\_\_  
Client's Site I.D.: Tecumseh Elementary School  
Client's Project I.D.: \_\_\_\_\_

LSL Sample Number	Client's Sample Identifications	Sample Date	Sample Time	Type		Matrix	Preserv. Added	Containers		Analyses	Free Cl (mg/L)	Pres. Check
				grab	comp.			#	size/type			
TE-001	Hit dish	10/28/20	5:10	x		PW	None	1	250 ml	001 A Lead		*7022
TE-002	Kit	"	5:13	x				1		002		
TE-003	Hit pot L	"	5:25	x				1		003		
TE-004	Hit pot R	"	5:28	x				1		004		
TE-005	Hit prep L	"	5:30	x				1		005		
TE-006	Hit prep R	"	5:32	x				1		006		
TE-007	Case	"	5:33	x				1		007		
TE-008	123	"	5:35	x				1		008		
TE-009	124	"	5:38	x				1		009		
TE-010	125	"	5:40	x				1		010		
TE-011	126	"	5:42	x				1		011		
TE-012	130	"	5:44	x				1		012		
TE-013	PAS	"	5:46	x				1		013		
TE-014	128	"	5:48	x				1		014		

Notes and Hazard identifications: Sample preserved upon Receipt at Lab

Custody Transfers		Date	Time
Sampled and Relinquished By:			
Print Name:	Signature:		
Received By:			
Relinquished By:	Received By:		
Relinquished By:	Received for Lab By:	10/28/20	13:20
Shipment Method:	Samples Received Intact: <input checked="" type="checkbox"/> N		

19.1°C



Life Science Laboratories, Inc.

5854 Butternut Drive  
East Syracuse, NY 13057

Phone # (315) 445-1900

Telefax # (315) 445-1104

# Chain of Custody Record

2017894

JamesvilleDewittCSD

7630



Client: Tecumseh Elementary School Phone # 315 445 8370  
 Address: 901 Nottingham Rd Fax # 315 445 9872  
Jamesville, NY 13078

Contact Person: \_\_\_\_\_ LSL Project #: \_\_\_\_\_  
 Client's Site I.D.: Tecumseh Elementary School  
 Client's Project I.D.: \_\_\_\_\_

Authorization:

LSL Sample Number	Client's Sample Identifications	Sample Date	Sample Time	Type		Matrix	Preserv. Added	Containers		LSL #	Analyses	Free Cl (mg/L)	Pres. Check
				grab	comp.			#	size/type				
TE-015	131	10/28/20	5:45	x		PW	None	1	250 mL	015 A	Lead		22
TE-016	132	"	5:48	x				1		016			
TE-017	2nd girls L	"	5:50	x				1		017			
TE-018	2nd girls C	"	5:51	x				1		018			
TE-019	2nd girls R	"	5:52	x				1		019			
TE-020	2nd cor	"	5:53	x				1		020			
TE-021	2nd Boys L	"	5:55	x				1		021			
TE-022	2nd Boys C	"	5:56	x				1		022			
TE-023	2nd Boys R	"	5:57	x				1		023			
TE-024	133	"	5:59	x				1		024			
TE-025	102	"	5:59	x				1		025			
<del>TE-026</del>	<del>101</del>	<del>"</del>	<del>6:02</del>	<del>x</del>				<del>1</del>					
TE-027	102 101	"	6:02	x				1		026			
TE-028	102	"	6:03	x				1		027			

Notes and Hazard identifications: ✓ Samples Preserved Upon Receipt at Lab

Custody Transfers		Date	Time
Sampled and Relinquished By:			
Print Name:	Signature:		
Received By:			
Relinquished By:	Received By:		
Relinquished By:	Received for Lab By:	<u>10/29/20</u>	<u>13:20</u>
Shipment Method:	Samples Received Intact: <u>✓</u> N		<u>19.1°C</u>

LSL

5854 Butternut Drive  
East Syracuse, NY 13057

Chain of Custody Record

Phone # (315) 445-1900

Telefax # (315) 445-1104

Client: Tecumseh Elementary School Phone # 315 445 8320  
Address: 901 Nottingham Rd Fax # 315 445 9872  
Jamesville, NY 13078

Contact Person: \_\_\_\_\_ LSL Project #: \_\_\_\_\_  
Client's Site I.D.: Tecumseh Elementary School  
Client's Project I.D.: \_\_\_\_\_

Authorization: \_\_\_\_\_

LSL Sample Number	Client's Sample Identifications	Sample Date	Sample Time	Type		Matrix	Preserv. Added	Containers		Analyses	Free Cl (mg/L)	Pres. Check
				grab	comp.			#	size/type			
<del>TE-028</del>	<del>102</del>	<del>10/28/20</del>	<del>6:07</del>	X		PW	None	1	250 ml.	<del>LSL# 028 A Lead</del>		<del>TC</del> <del>LH</del>
TE-029	104	"	6:04	X				1		029 029		
TE-030	104	"	6:05	X				1		030 030		
TE-031	103	"	6:10	X				1		031 031		
TE-032	103	"	6:07	X				1		031 032		
TE-034	106	"	6:22	X				1		032 033		
TE-037	105	"	6:10	X				1		033 034		
TE-038	108	"	6:15	X				1		034 035		
TE-040	107	"	6:15	X				1		035 036		
TE-041	110	"	6:15	X				1		036 037		
TE-042	109	"	6:16	X				1		037 038		
TE-043	109	"	6:17	X				1		038 039		
TE-045	A-T L	"	6:17	X				1		039 040		
TE-046	A-T C	"	6:18	X				1		040 041		✓

①

① Duplicate from prev. COC page TJN 11/05/2020 300

Notes and Hazard identifications:  
\* Sample Preserved Upon Receipt at Lab

Custody Transfers		Date	Time
Sampled and Relinquished By:			
Print Name:	Signature:		
Received By:			
Relinquished By:	Received By:		
Relinquished By:	Received for Lab By:	10/28/20	13:20
Shipment Method:		Samples Received Intact: <input checked="" type="checkbox"/> N	

19.1°C



Life Science Laboratories, Inc.

5854 Butternut Drive  
East Syracuse, NY 13057

Phone # (315) 445-1900

Telefax # (315) 445-1104

### Chain of Custody Record

2017894

JamesvilleDewittCSD

7630

<b>Client:</b> <u>Tecumseh Elementary School</u>	<b>Phone #</b> <u>315 445 8320</u>	<b>Contact Person:</b>	<b>LSL Project #:</b>
<b>Address:</b> <u>901 Nottingham Rd Jamesville, NY 13078</u>	<b>Fax #</b> <u>315 445 9872</u>		
<b>Authorization:</b>		<b>Client's Site I.D.:</b> <u>Tecumseh Elementary School</u>	
		<b>Client's Project I.D.:</b>	

LSL Sample Number	Client's Sample Identifications	Sample Date	Sample Time	Type		Matrix	Preserv. Added	Containers		Analyses	Free Cl (mg/L)	Pres. Check
				grab	comp.			#	size/type			
TE-047	A+R	10/28/20	6:20	x		PW	None	1	250 ml	LSL # 042 A Lead		T022
TE-048	A+R WR	"	6:20	x				1		041 043		
TE-049	A+R WC	"	6:22	x				1		042 044		
TE-050	staff	"	6:18	x				1		043 045		
TE-052	Acc Lav	"	6:20	x				1		044 046		
TE-091	115	"	8:00	x				1		045 047		
TE-053	boys gym E	"	6:18	x				1		046 048		
TE-054	boys gym L	"	6:17	x				1		047 049		
TE-055	120	"	6:20	x				1		048 050		
② TE-056	cor-nurse	"	6:30	x				1		049 051		
TE-059	116	"	6:20	x				1		050 052		
TE-057	9th Ltrm	"	6:20	x				1		051 053		
TE-061	119	"	6:40	x				1		052 054		
TE-060	117	"	6:30	x				1		053 055		

<b>Notes and Hazard identifications:</b> * Sample Preserved Upon Receipt at Lab ② No sample received, 75 11-23-20	<b>Custody Transfers</b>		<b>Date</b>	<b>Time</b>
	<b>Sampled and Relinquished By:</b>			
	<b>Print Name:</b>	<b>Signature:</b>		
	<b>Received By:</b>			
	<b>Relinquished By:</b>	<b>Received By:</b>		
<b>Relinquished By:</b>	<b>Received for Lab By:</b> <i>[Signature]</i>	10/28/20	13:20	
<b>Shipment Method:</b>	<b>Samples Received Intact:</b> <input checked="" type="checkbox"/> Y <input type="checkbox"/> N		19.1°C	



Life Science Laboratories, Inc.

5854 Butternut Drive  
East Syracuse, NY 13057

Phone # (315) 445-1900

Telefax # (315) 445-1104

Chain of Custody Record

2017894

JamesvilleDewittCSD

7630

Client: Tecumseh Elementary School Phone # 315 445 8320  
Address: 901 Northway Rd Fax # 315 445 9872  
Jamesville, NY 13078

Contact Person: \_\_\_\_\_ LSL Project #: \_\_\_\_\_  
Client's Site I.D.: \_\_\_\_\_  
Client's Project I.D.: \_\_\_\_\_

LSL Sample Number	Client's Sample Identifications	Sample Date	Sample Time	Type		Matrix	Preserv. Added	Containers		LSL #	Analyses	Free Cl (mg/L)	Pres. Check
				grab	comp.			#	size/type				
TE-062	118	10/18/20	6:50	x		PW	#11/2/3 None	1	250 mL	45L# 056A	Lead		x T622
TE-063	boy LHRm	"	6:50	x				1		054 057			
TE-064	boy 4th Rm LAU	"	6:55	x				1		055 058			
TE-065	girl 1st Rm	"	6:58	x				1		056 059			
TE-067	146	"	7:05	x				1		057 060			
TE-066	144	"	7:00	x				1		058 061			
TE-069	4th 3rd R	"	7:15	x				1		059 062			
TE-070	4th 3rd C	"	7:15	x				1		060 063			
TE-071	4th 3rd L	"	7:18	x				1		061 064			
TE-073	4th boys C	"	7:20	x				1		062 065			
TE-068	145	"	7:16	x				1		063 066			✓
TE-050	ART	"	6:23	x				1		067			
TE-056	116	"	6:30	x				1		068			
				x				1					

\*\*  
\*\*

Notes and Hazard identifications:  
\* Samples Preserved Upon Receipt at Lab  
\*\* EXTRA Samples received. Add To CCL for Analysis per Jason Crowther's request. 11-6-20

Custody Transfers		Date	Time
Sampled and Relinquished By:			
Print Name:	Signature:		
Received By:			
Relinquished By:	Received By:		
Relinquished By:	Received for Lab By:	10/28/20	13:20
Shipment Method:		Samples Received Intact: <input checked="" type="checkbox"/> Y <input type="checkbox"/> N	
		19.1°C	