

Sample Identification # and Location	Date/Time Collected	Date/Time Analyzed	Container ID	Analyte	Results	NYSDOH Action Level	Units				
1	7/30/2025 05:00	8/7/2025 18:28	70370432001	Lead	3.0	5	ug/L	Middle School	Kitchen	Left Pot Wash Sink	
2	7/30/2025 05:00	8/7/2025 18:29	70370432002	Lead	4.3	5	ug/L	Middle School	Kitchen	Right Pot Wash Sink	
3	7/30/2025 05:00	8/7/2025 18:31	70370432003	Lead	52.1	5	ug/L	Middle School	Kitchen	Hand Sink	
4	7/30/2025 05:00	8/7/2025 18:35	70370432004	Lead	<1.0	5	ug/L	Middle School	Custodial	Slop Sink	
5	7/30/2025 05:00	8/8/2025 15:43	70370432005	Lead	2.5	5	ug/L	High School	Trainers hall IM faucet	SC	
6	7/30/2025 05:00	8/8/2025 15:44	70370432006	Lead	1.6	5	ug/L	High School	upper concession	SC	North side
7	7/30/2025 05:00	8/7/2025 18:37	70370432007	Lead	1.2	5	ug/L	High School	Hall of Fame Concession	sink	sink
8	7/30/2025 05:00	8/7/2025 18:38	70370432008	Lead	1.2	5	ug/L	High School	G02 Breakroom	FSC	sink
9	7/30/2025 05:00	8/7/2025 18:40	70370432009	Lead	4.0	5	ug/L	High School	Kitchen wash bay	KC	right side
10	7/30/2025 05:00	8/7/2025 18:42	70370432010	Lead	3.5	5	ug/L	High School	Cafeteria	Combi hose	1
11	7/30/2025 05:00	8/7/2025 18:43	70370432011	Lead	3.0	5	ug/L	TEC	kithchen pot sink left	kc	
12	7/30/2025 05:00	8/7/2025 18:45	70370432012	Lead	7.6	5	ug/L	TEC	124	cf	
13	7/30/2025 05:00	8/8/2025 15:46	70370432013	Lead	10.9	5	ug/L	TEC	126	cf	
14	7/30/2025 05:00	8/8/2025 15:50	70370432014	Lead	18.9	5	ug/L	TEC	130	cf	
15	7/30/2025 05:00	8/7/2025 18:46	70370432015	Lead	4.4	5	ug/L	TEC	PPS	cf	
16	7/30/2025 05:00	8/7/2025 18:48	70370432016	Lead	4.9	5	ug/L	TEC	131	cf	
17	7/30/2025 05:00	8/7/2025 18:50	70370432017	Lead	8.1	5	ug/L	TEC	2nd grd corridor	WC	
18	7/30/2025 05:00	8/8/2025 13:18	70370432018	Lead	214	5	ug/L	TEC	114	cf	
19	7/30/2025 05:00	8/8/2025 13:23	70370432019	Lead	11.9	5	ug/L	TEC	108	wc	
20	7/30/2025 05:00	8/8/2025 13:27	70370432020	Lead	6.8	5	ug/L	TEC	109	wc	
21	7/30/2025 05:00	8/8/2025 13:32	70370432021	Lead	8.3	5	ug/L	TEC	corridor by nurse	wc	
22	7/30/2025 05:00	8/8/2025 15:52	70370432022	Lead	11.7	5	ug/L	TEC	boys locker rm	wc	
23	7/30/2025 05:00	8/8/2025 13:36	70370432023	Lead	2.0	5	ug/L	TEC	107	cr	New
24	7/30/2025 05:00	8/8/2025 13:38	70370432024	Lead	10.1	5	ug/L	TEC	110	wc	New
25	7/30/2025 05:00	8/8/2025 15:53	70370432025	Lead	12.5	5	ug/L	TEC	112	wc	New
26	7/30/2025 05:00	8/8/2025 13:39	70370432026	Lead	<1.0	5	ug/L	JES	206	CF	Sink
27	7/30/2025 05:00	8/8/2025 15:55	70370432027	Lead	11.2	5	ug/L	JES	Art Rm	cf	east right
28	7/30/2025 05:00	8/8/2025 16:03	70370432028	Lead	7.3	5	ug/L	JES	107	CF	Aid Room
29	7/30/2025 05:00	8/8/2025 13:41	70370432029	Lead	9.0	5	ug/L	JES	104	WC	Fountain
30	7/30/2025 05:00	8/8/2025 16:13	70370432030	Lead	3.8	5	ug/L	JES	105	CF	East
31	7/30/2025 05:00	8/8/2025 13:43	70370432031	Lead	1.6	5	ug/L	JES	102	CF	West
32	7/30/2025 05:00	8/8/2025 13:44	70370432032	Lead	<1.0	5	ug/L	JES	Lower Hall	WC	Fountain
33	7/30/2025 05:00	8/8/2025 16:15	70370432033	Lead	8.0	5	ug/L	JES	101	CF	Wall
34	7/30/2025 05:00	8/8/2025 16:16	70370432034	Lead	8.4	5	ug/L	JES	103	CF	Wall
35	7/30/2025 05:00	8/8/2025 16:18	70370432035	Lead	4.6	5	ug/L	JES	102	CF	Sink
36	7/30/2025 05:00	8/8/2025 13:46	70370432036	Lead	10.1	5	ug/L	MDES	Gym	WC	
37	7/30/2025 05:00	8/8/2025 16:19	70370432037	Lead	16.5	5	ug/L	MDES	Libraray	CF	
38	7/30/2025 05:00	8/8/2025 13:47	70370432038	Lead	12.0	5	ug/L	MDES	social workers office	cf	
39	7/30/2025 05:00	8/8/2025 13:49	70370432039	Lead	10.0	5	ug/L	MDES	16	cf	
40	7/30/2025 05:00	8/8/2025 13:51	70370432040	Lead	7.6	5	ug/L	MDES	17	cf	
41	7/30/2025 05:00	8/8/2025 13:55	70370432041	Lead	15.5	5	ug/L	MDES	18	cf	
42	7/30/2025 05:00	8/8/2025 13:57	70370432042	Lead	11.3	5	ug/L	MDES	19	cf	
43	7/30/2025 05:00	8/8/2025 13:58	70370432043	Lead	6.8	5	ug/L	MDES	20	cf	
44	7/30/2025 05:00	8/8/2025 14:00	70370432044	Lead	13.4	5	ug/L	MDES	22	cf	
45	7/30/2025 05:00	8/8/2025 14:02	70370432045	Lead	7.8	5	ug/L	MDES	23	cf	
46	7/30/2025 05:00	8/8/2025 14:03	70370432046	Lead	6.1	5	ug/L	MDES	24	cf	
47	7/30/2025 05:00	8/8/2025 14:05	70370432047	Lead	11.3	5	ug/L	MDES	22	cf sm sink	
48	7/30/2025 05:00	8/8/2025 14:09	70370432048	Lead	5.4	5	ug/L	MDES	21	cf sm sink	
49	7/30/2025 05:00	8/8/2025 14:17	70370432049	Lead	13.2	5	ug/L	MDES	19	cf sm sink	
50	7/30/2025 05:00	8/8/2025 14:21	70370432050	Lead	7.8	5	ug/L	MDES	18	cf sm sink	

NYSDOH Action Level for Lead In Schools of 5 ppb