

Sample Identification # and Location	Date/Time Collected	Date/Time Analyzed	Container ID	Analyte	Results	NYSDOH Action Level	Units				
1	9/26/2025 6:30	10/10/2025 17:16	70382571001	Lead	52.1	5	ug/L	Middle School	Kitchen	Hand Sink	
2	9/26/2025 6:30	10/10/2025 17:17	70382571002	Lead	7.6	5	ug/L	TEC	124	cf	
3	9/26/2025 6:30	10/10/2025 15:07	70382571003	Lead	10.9	5	ug/L	TEC	126	cf	
4	9/26/2025 6:30	10/10/2025 17:22	70382571004	Lead	18.9	5	ug/L	TEC	130	cf	
5	9/26/2025 6:30	10/10/2025 17:23	70382571005	Lead	8.1	5	ug/L	TEC	2nd grd corridor	WC	
13	9/26/2025 6:30	10/10/2025 17:24	70382571013	Lead	11.2	5	ug/L	JES	Art Rm	cf	east right
14	9/26/2025 6:30	10/10/2025 15:09	70382571014	Lead	7.3	5	ug/L	JES	107	CF	Aid Room
16	9/26/2025 6:30	10/10/2025 17:29	70382571016	Lead	8.0	5	ug/L	JES	101	CF	Wall
17	9/26/2025 6:30	10/10/2025 15:10	70382571017	Lead	8.4	5	ug/L	JES	103	CF	Wall
18	9/26/2025 6:30	10/10/2025 17:33	70382571018	Lead	10.1	5	ug/L	MDES	Gym	WC	
19	9/26/2025 6:30	10/10/2025 17:41	70382571019	Lead	16.5	5	ug/L	MDES	Libraray	CF	
20	9/26/2025 6:30	10/10/2025 17:42	70382571020	Lead	12.0	5	ug/L	MDES	social workers office	cf	
21	9/26/2025 6:30	10/10/2025 17:44	70382571021	Lead	10.0	5	ug/L	MDES	16	cf	
22	9/26/2025 6:30	10/10/2025 17:45	70382571022	Lead	7.6	5	ug/L	MDES	17	cf	
23	9/26/2025 6:30	10/10/2025 17:47	70382571023	Lead	15.5	5	ug/L	MDES	18	cf	
24	9/26/2025 6:30	10/10/2025 17:48	70382571024	Lead	11.3	5	ug/L	MDES	19	cf	
25	9/26/2025 6:30	10/10/2025 17:49	70382571025	Lead	6.8	5	ug/L	MDES	20	cf	
26	9/26/2025 6:30	10/10/2025 17:51	70382571026	Lead	13.4	5	ug/L	MDES	22	cf	
27	9/26/2025 6:30	10/10/2025 17:52	70382571027	Lead	7.8	5	ug/L	MDES	23	cf	
28	9/26/2025 6:30	10/10/2025 17:57	70382571028	Lead	6.1	5	ug/L	MDES	24	cf	
29	9/26/2025 6:30	10/10/2025 17:58	70382571029	Lead	11.3	5	ug/L	MDES	22	cf sm sink	
30	9/26/2025 6:30	10/10/2025 18:00	70382571030	Lead	5.4	5	ug/L	MDES	21	cf sm sink	
31	9/26/2025 6:30	10/10/2025 18:01	70382571031	Lead	13.2	5	ug/L	MDES	19	cf sm sink	
32	9/26/2025 6:30	10/10/2025 18:03	70382571032	Lead	7.8	5	ug/L	MDES	18	cf sm sink	
34	9/26/2025 6:30	10/10/2025 18:04	70382571034	Lead	<1.0	5	ug/L	TEC	Hall Fountain	WC	SE Hall

NYSDOH Action Level for Lead In Schools of 5 ppb